

QC - Concrete Cube Testing Report															
Company:	Nigrit Estimating														
Project:	Nigrit Homes-II														
Report for Month:	Feb-Mar-17														
Prepared By:	P.Sai Kumar.														
Date:	12-06-2017														
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
5729	06-02-2017	Site Mix	M20	Anand		119	footing		13-2-17	(7)	14.0	320.0	14.2	14.6	✓
											14.0	325.0	14.4		
											14.0	340.0	15.1		
5729	06-02-2017	Site Mix	M20	Anand		119	footing		5-3-17	(27)	20.0	455.0	20.2	20.2	✓
											20.0	450.0	20.0	20.2	
											20.0	460.0	20.4		
5730	07-02-2017	Site Mix	M20	Anand		101	footing		13-2-17	(6)	14.0	320.0	14.2	14.3	✓
											14.0	315.0	14.0		
											14.0	330.0	14.7		
5730	07-02-2017	Site Mix	M20	Anand		101	footing		5-3-17	(26)	20.0	460.0	20.4	20.3	✓
											20.0	450.0	20.0		
											20.0	460.0	20.4		
5731	08-02-2017	Site Mix	M20	Anand		111	plinthbeam		16-2-17	(8)	14.0	310.0	13.8	14.2	✓
											14.0	315.0	14.0		
											14.0	335.0	14.9		
5731	08-02-2017	Site Mix	M20	Anand		111	plinthbeam		7-3-17	(27)	20.0	460.0	20.4	20.1	✓
											20.0	445.0	19.8		
											20.0	455.0	20.2		
5732	08-02-2017	Site Mix	M20	Anand		136	plinthbeam		16-2-17	(8)	14.0	325.0	14.4	14.4	✓
											14.0	330.0	14.7		
											14.0	315.0	14.0		
5732	08-02-2017	Site Mix	M20	Anand		136	plinthbeam		7-3-17	(27)	20.0	470.0	20.9	20.5	✓
											20.0	460.0	20.4		
											20.0	455.0	20.2		
5733	10-02-2017	Site Mix	M20	Anand		94	plinthbeam		18-2-17	(8)	14.0	320.0	14.2	14.7	✓
											14.0	335.0	14.9		
											14.0	335.0	14.9		
5733	10-02-2017	Site Mix	M20	Anand		94	plinthbeam		9-3-17	(27)	20.0	465.0	20.7		

[illegible]

5740	18-02-2017	Site Mix	M25	Anand		82	col	1	25-2-17	(7)	17.5	400.0	17.8	17.6	✓
											17.5	390.0	17.3	17.6	
											17.5	395.0	17.6		
5740	18-02-2017	Site Mix	M25	Anand		82	col	1	17-3-17	(27)	25.0	580.0	25.8	25.6	✓
											25.0	570.0	25.3	25.6	
											25.0	575.0	25.6		
5741	17-02-2017	Site Mix	M25	Anand		100	col	1	25-2-17	(8)	17.5	395.0	17.6	17.8	✓
											17.5	400.0	17.8		
											17.5	405.0	18.0		
5741	17-02-2017	Site Mix	M25	Anand		100	col	1	16-3-17	(27)	25.0	575.0	25.6	25.6	✓
											25.0	570.0	25.3	25.6	
											25.0	580.0	25.8		
5742	18-02-2017	Site Mix	M20	Anand		120	footing		25-2-17	(7)	14.0	315.0	14.0	14.4	✓
											14.0	335.0	14.9	14.4	
											14.0	325.0	14.4		
5742	18-02-2017	Site Mix	M20	Anand		120	footing		17-3-17	(27)	20.0	460.0	20.4	20.7	✓
											20.0	465.0	20.7	20.7	
											20.0	470.0	20.9		
5743	20-02-2017	Site Mix	M25	Anand		83	col	1	27-2-17	(7)	17.5	400.0	17.8	17.8	✓
											17.5	390.0	17.3	17.8	
											17.5	410.0	18.2		
5743	20-02-2017	Site Mix	M25	Anand		83	col	1	19-3-17	(27)	25.0	575.0	25.6	25.5	✓
											25.0	570.0	25.3	25.5	
											25.0	575.0	25.6		
5744	23-02-2017	Site Mix	M25	Anand		88	col	1	1-3-17	(6)	17.5	410.0	18.2	17.9	✓
											17.5	390.0	17.3	17.9	
											17.5	405.0	18.0		
5744	23-02-2017	Site Mix	M25	Anand		88	col	1	22-3-17	(27)	25.0	575.0	25.6	25.5	✓
											25.0	570.0	25.3	25.5	
											25.0	575.0	25.6		
5745	23-02-2017	Site Mix	M20	Anand		126	footing		1-3-17	(6)	14.0	325.0	14.4	14.4	✓
											14.0	330.0	14.7	14.4	
											14.0	315.0	14.0		
5745	23-02-2017	Site Mix	M20	Anand		126	footing		22-3-17	(27)	20.0	470.0	20.9	20.4	✓
											20.0	450.0	20.0	20.4	
											20.0	455.0	20.2		
5746	24-02-2017	Site Mix	M25	Anand		111	col	1	2-3-17	(6)	17.5	395.0	17.6	17.6	✓
											17.5	390.0	17.3	17.6	
											17.5	405.0	18.0		

5746	24-02-2017	Site Mix	M25	Anand		111	col	1	22-3-17	(26)	25.0	570.0	25.3	25.4	✓
											25.0	570.0	25.3	25.4	
											25.0	575.0	25.6		
5747	24-02-2017	Site Mix	M20	Anand		98	footing		2-3-17	(6)	14.0	325.0	14.4		✓
											14.0	320.0	14.2	14.4	
											14.0	330.0	14.7		
5747	24-02-2017	Site Mix	M20	Anand		98	footing		22-3-17	(26)	20.0	470.0	20.9		✓
											20.0	475.0	21.1	20.8	
											20.0	460.0	20.4		
5748	24-02-2017	Site Mix	M25	Anand		92	col	1	2-3-17	(6)	17.5	395.0	17.6		✓
											17.5	390.0	17.3	17.6	
											17.5	400.0	17.8		
5748	24-02-2017	Site Mix	M25	Anand		92	col	1	22-3-17	(26)	25.0	560.0	24.9		✓
											25.0	570.0	25.3	25.1	
											25.0	565.0	25.1		
5749	02-03-2017	Site Mix	M25	Anand		93	col	1	10-3-17	(8)	17.5	395.0	17.6		✓
											17.5	400.0	17.8	17.7	
											17.5	400.0	17.8		
5749	02-03-2017	Site Mix	M25	Anand		93	col	1	29-3-17	(27)	25.0	560.0	24.9	25.1	✓
											25.0	560.0	24.9	25.1	
											25.0	575.0	25.6		
5750	02-03-2017	Site Mix	M25	Anand		94	col	1	10-3-17	(8)	17.5	395.0	17.6		✓
											17.5	390.0	17.3	17.6	
											17.5	405.0	18.0		
5750	02-03-2017	Site Mix	M25	Anand		94	col	1	29-3-17	(27)	25.0	570.0	25.3	25.2	✓
											25.0	570.0	25.3	25.2	
											25.0	560.0	24.9		
5751	02-03-2017	Site Mix	M25	Anand		136	col	1	10-3-17	(8)	17.5	400.0	17.8		✓
											17.5	390.0	17.3	17.7	
											17.5	405.0	18.0		
5751	02-03-2017	Site Mix	M25	Anand		136	col	1	29-3-17	(27)	25.0	565.0	25.1	25.2	✓
											25.0	560.0	24.9	25.2	
											25.0	575.0	25.6		
5752	03-03-2017	Site Mix	M25	Anand		95	col	1	10-3-17	(7)	17.5	390.0	17.3	17.5	✓
											17.5	390.0	17.3	17.5	
											17.5	400.0	17.8		
5752	03-03-2017	Site Mix	M25	Anand		95	col	1	29-3-17	(26)	25.0	570.0	25.3	25.2	✓
											25.0	565.0	25.1	25.2	

5753	03-03-2017	Site Mix	M25	Anand		96	col	1	10-3-17	(7)	17.5	395.0	17.6		✓
											17.5	390.0	17.3	17.6	
											17.5	400.0	17.8		
5753	03-03-2017	Site Mix	M25	Anand		96	col	1	29-3-17	(26)	25.0	550.0	24.4	25.0	✓
											25.0	565.0	25.1		
											25.0	575.0	25.6		
5754	07-03-2017	Site Mix	M20	Anand		87	plinthbeam		15-3-17	(8)	14.0	315.0	14.0	14.2	✓
											14.0	325.0	14.4		
											14.0	320.0	14.2		
5754	07-03-2017	Site Mix	M20	Anand		87	plinthbeam		3-4-17	(27)	20.0	450.0	20.0	20.3	✓
											20.0	455.0	20.2		
											20.0	465.0	20.7		
5755	07-03-2017	Site Mix	M20	Anand		112	plinthbeam		15-3-17	(8)	14.0	335.0	14.9		✓
											14.0	325.0	14.4	14.7	
											14.0	330.0	14.7		
5755	07-03-2017	Site Mix	M20	Anand		112	plinthbeam		3-4-17	(27)	20.0	455.0	20.2	14.4	✓
											20.0	56.0	2.5		
											20.0	460.0	20.4		
5756	08-03-2017	Site Mix	M20	Anand		134	footing		15-3-17	(7)	14.0	340.0	15.1	14.8	✓
											14.0	325.0	14.4		
											14.0	335.0	14.9		
5756	08-03-2017	Site Mix	M20	Anand		134	footing		3-4-17	(26)	20.0	465.0	20.7	20.5	✓
											20.0	460.0	20.4		
											20.0	460.0	20.4		
5757	13-03-2017	Site Mix	M20	Anand		91	slab	1	20-3-17	(7)	14.0	320.0	14.2	14.6	✓
											14.0	325.0	14.4		
											14.0	340.0	15.1		
5757	13-03-2017	Site Mix	M20	Anand		91	slab	1	9-4-17	(27)	20.0	460.0	20.4	20.4	✓
											20.0	450.0	20.0		
											20.0	470.0	20.9		
5758	15-03-2017	Site Mix	M20	Anand		85	plinthbeam		21-3-17	(6)	14.0	330.0	14.7	14.6	✓
											14.0	330.0	14.7		
											14.0	325.0	14.4		
5758	15-03-2017	Site Mix	M20	Anand		85	plinthbeam		12-4-17	(28)	20.0	455.0	20.2	20.2	✓
											20.0	450.0	20.0		
											20.0	460.0	20.4		
5759	15-03-2017	Site Mix	M20	Anand		86	plinthbeam		21-3-17	(6)	14.0	330.0	14.7		

									140	335.0	149	14.7	✓
									140	325.0	144		
5759	15-03-2017	Site Mix	M20	Anand		86	plinthbeam	12-4-17	(28)	20.0	455.0	20.2	✓
										20.0	465.0	20.7	
										20.0	460.0	20.4	
5760	15-03-2017	Site Mix	M20	Anand		113	footing	21-3-17	(6)	14.0	335.0	14.9	✓
										14.0	335.0	14.9	
										14.0	325.0	14.4	
5760	15-03-2017	Site Mix	M20	Anand		113	footing	12-4-17	(28)	20.0	450.0	20.0	✓
										20.0	450.0	20.0	
										20.0	460.0	20.4	
5761	20-03-2017	Site Mix	M20	Anand		122	footing	27-3-17	(7)	14.0	315.0	14.0	✓
										14.0	325.0	14.4	
										14.0	330.0	14.7	
5761	20-03-2017	Site Mix	M20	Anand		122	footing	17-4-17	(28)	20.0	460.0	20.4	✓
										20.0	450.0	20.0	
										20.0	460.0	20.4	
5762	20-03-2017	Site Mix	M20	Anand		125	footing	27-3-17	(7)	14.0	310.0	13.8	✓
										14.0	320.0	14.2	
										14.0	330.0	14.7	
5762	20-03-2017	Site Mix	M20	Anand		125	footing	17-4-17	(28)	20.0	460.0	20.4	✓
										20.0	465.0	20.7	
										20.0	460.0	20.4	
5763	23-03-2017	Site Mix	M20	Anand		167	footing	30-3-17	(7)	14.0	330.0	14.7	✓
										14.0	330.0	14.7	
										14.0	325.0	14.4	
5763	23-03-2017	Site Mix	M20	Anand		167	footing	20-4-17	(28)	20.0	460.0	20.4	✓
										20.0	460.0	20.4	
										20.0	465.0	20.7	
5764	23-03-2017	Site Mix	M20	Anand		84	plinthbeam	30-3-17	(7)	14.0	320.0	14.2	✓
										14.0	315.0	14.0	
										14.0	330.0	14.7	
5764	23-03-2017	Site Mix	M20	Anand		84	plinthbeam	20-4-17	(28)	20.0	470.0	20.9	✓
										20.0	460.0	20.4	
										20.0	455.0	20.2	