



Location	Phase to phase	Phase to Nutral	Earth to nutral	Remarks
Main Meter/panel board	396 Volts	229 Volts	NA	Earth pit excavation going on
V-73 Panal board	396	226 } 223 }	Na	Bore motor off time
V-73 Panel board	383	223 }	Na	Bore motor On time
V-1 Panel board	396	225	Na	
V-22 at Panel board	389	230 }	Na	Bore motor Off Time
V-22 at Panel Board	395	230 }	Na	Bore motor On time Single Phase
Sump DB Board	395	232 }	Na	Sump Motors Off time
Sump DB Board	378	253 }	Na	Sump motor On time
Clubhouse DB Board	395	229	Na	RO Plant and Fabrication work off time
RO Plant DB Board	398	228	Na	RO Plant Off Time
RO Plant DB Board	353	258	Na	RO Plant On time/and Minimum required 420 Volts