

QC - Concrete Cube Testing Report.															
Company:	Nigrit Estates.														
Project:	Nilgiri Homes-II														
Report for Month:	Jan & Feb-17														
Prepared By:	P.Sai Kumar.														
Date:	13-03-2017														
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
5717	13-01-2017	Site Mix	M20	Anand		81	Plinthbeam		20-1-17	(7)	14.0	345.0	15.3	15.1	✓
											14.0	335.0	14.9		
											14.0	340.0	15.1		
5717	13-01-2017	Site Mix	M20	Anand		81	Plinthbeam		9-2-17	(27)	20.0	470.0	20.9	20.7	✓
											20.0	460.0	20.4		
											20.0	465.0	20.7		
5718	13-01-2017	Site Mix	M20	Anand		91	Plinthbeam		20-1-17	(7)	14.0	350.0	15.6	15.3	✓
											14.0	340.0	15.1		
											14.0	340.0	15.1		
5718	13-01-2017	Site Mix	M20	Anand		91	Plinthbeam		9-2-17	(27)	20.0	465.0	20.7	20.5	✓
											20.0	455.0	20.2		
											20.0	465.0	20.7		
5719	19-01-2017	Site Mix	M20	Anand		82	Plinthbeam		26-1-17	(7)	14.0	340.0	15.1	15.1	✓
											14.0	340.0	15.1		
											14.0	340.0	15.1		
5719	19-01-2017	Site Mix	M20	Anand		82	Plinthbeam		16-2-17	(28)	20.0	465.0	20.7	20.7	✓
											20.0	465.0	20.7		
											20.0	470.0	20.9		
5720	20-01-2017	Site Mix	M20	Anand		83	Plinthbeam		27-1-17	(7)	14.0	345.0	15.3	15.2	✓
											14.0	340.0	15.1		
											14.0	340.0	15.1		
5720	20-01-2017	Site Mix	M20	Anand		83	Plinthbeam		16-2-17	(27)	20.0	470.0	20.9	20.8	✓
											20.0	465.0	20.7		
											20.0	470.0	20.9		

5721	21-01-2017	Site Mix	M20	Anand		115	footing		27-1-17	(6)	14.0	350.0	15.6			✓
											14.0	340.0	15.1	15.3		
											14.0	340.0	15.1			
5721	21-01-2017	Site Mix	M20	Anand		115	footing		16-2-17	(26)	20.0	465.0	20.7			✓
											20.0	465.0	20.7	20.6		
											20.0	460.0	20.4			
5722	22-01-2017	Site Mix	M20	Anand		116	footing		29-1-17	(7)	14.0	330.0	14.7			✓
											14.0	340.0	15.1	15.0		
											14.0	340.0	15.1			
5722	22-01-2017	Site Mix	M20	Anand		116	footing		18-2-17	(27)	20.0	455.0	20.2			✓
											20.0	465.0	20.7	20.4		
											20.0	460.0	20.4			
5723	28-01-2017	Site Mix	M20	Anand		97	footing		5-2-17	(8)	14.0	345.0	15.3			✓
											14.0	350.0	15.6	15.3		
											14.0	340.0	15.1			
5723	28-01-2017	Site Mix	M20	Anand		97	footing		26-2-17	(26)	20.0	455.0	20.2			✓
											20.0	465.0	20.7	20.6		
											20.0	470.0	20.9			
5724	31-01-2017	Site Mix	M20	Anand		135	Plinthbeam		7-2-17	(7)	14.0	345.0	15.3			✓
											14.0	340.0	15.1	15.2		
											14.0	340.0	15.1			
5724	31-01-2017	Site Mix	M20	Anand		135	Plinthbeam		26-2-17	(26)	20.0	470.0	20.9			✓
											20.0	465.0	20.7	20.8		
											20.0	470.0	20.9			
5725	31-01-2017	Site Mix	M20	Anand		86	footing		7-2-17	(7)	14.0	345.0	15.3			✓
											14.0	340.0	15.1	15.1		
											14.0	335.0	14.9			
5725	31-01-2017	Site Mix	M20	Anand		86	footing		26-2-17	(26)	20.0	460.0	20.4			✓
											20.0	455.0	20.2	20.4		
											20.0	465.0	20.7			
5726	04-02-2017	Site Mix	M20	Anand		88	Plinthbeam		11-2-17	(7)	14.0	345.0	15.3			✓
											14.0	340.0	15.1	15.2		
											14.0	340.0	15.1			
5726	04-02-2017	Site Mix	M20	Anand		88	Plinthbeam		4-3-17	(28)	20.0	470.0	20.9			✓
											20.0	465.0	20.7	20.8		
											20.0	470.0	20.9			

5727	04-02-2017	Site Mix	M20	Anand	100	Plinthbeam	11-2-17	(7)	14.0	335.0	14.9	15.0	✓
									14.0	340.0	15.1		
									14.0	340.0	15.1		
5727	04-02-2017	Site Mix	M20	Anand	100	Plinthbeam	4-3-17	(28)	20.0	455.0	20.2	20.6	✓
									20.0	465.0	20.7		
									20.0	470.0	20.9		
5728	04-02-2017	Site Mix	M20	Anand	92	Plinthbeam	11-2-17	(7)	14.0	345.0	15.3	15.1	✓
									14.0	335.0	14.9		
									14.0	340.0	15.1		
5728	04-02-2017	Site Mix	M20	Anand	92	Plinthbeam	4-3-17	(28)	20.0	455.0	20.2	20.2	✓
									20.0	450.0	20.0		
									20.0	460.0	20.4		