

QC - Concrete Cube Testing Report															
Company: Nigiri Estates			Project: Nigiri Homes-II			Report for Month: May & June -19			Prepared By: S.Sunil Kumar			Date: 05-07-2019			
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
5388	18-05-2019	Site Mix	M20	Anand		183	Slab	1	25-5-19	7	14.0	320.0	14.2	14.2	
											14.0	325.0	14.4	14.2	
											14.0	315.0	14.0		
5388	18-05-2019	Site Mix	M20	Anand		183	Slab	1	14-6-19	27	20.0	445.0	19.8		
											20.0	460.0	20.4	20.1	
											20.0	455.0	20.2		
5389	18-05-2019	Site Mix	M20	Anand		184	Slab	1	25-5-19	7	14.0	315.0	14.0	14.4	14.4
											14.0	325.0	14.4		
											14.0	330.0	14.7		
5389	18-05-2019	Site Mix	M20	Anand		184	Slab	1	14-6-19	27	20.0	475.0	21.1		
											20.0	460.0	20.4	20.6	
											20.0	455.0	20.2		
5390	18-05-2019	Site Mix	M20	Anand		185	Slab	1	25-5-19	7	14.0	320.0	14.2	14.4	
											14.0	315.0	14.0		
											14.0	335.0	14.9		
5390	18-05-2019	Site Mix	M20	Anand		185	Slab	1	14-6-19	27	20.0	480.0	21.3		
											20.0	460.0	20.4	20.5	
											20.0	445.0	19.8		
5391	23-05-2019	Site Mix	M20	Anand		180	Slab	3	31-5-19	8	14.0	320.0	14.2		
											14.0	330.0	14.7	14.7	
											14.0	340.0	15.1		
5391	23-05-2019	Site Mix	M20	Anand		180	Slab	3	20-6-19	28	20.0	465.0	20.7		
											20.0	470.0	20.9	20.6	
											20.0	455.0	20.2		

5392	23-05-2019	Site Mix	M20	Anand	181	Slab	2	31-5-19	8	14.0	315.0	14.0		
										14.0	320.0	14.2	14.5	
										14.0	345.0	15.3		
5392	23-05-2019	Site Mix	M20	Anand	181	Slab	2	19-6-19	27	20.0	450.0	20.0		
										20.0	465.0	20.7	20.4	
										20.0	460.0	20.4		
5393	23-05-2019	Site Mix	M20	Anand	182	Slab	2	30-5-19	7	14.0	325.0	14.4		
										14.0	330.0	14.7	14.7	
										14.0	340.0	15.1		
5393	23-05-2019	Site Mix	M20	Anand	182	Slab	2	19-6-19	27	20.0	465.0	20.7		
										20.0	470.0	20.9	20.7	
										20.0	460.0	20.4		
5394	28-05-2019	Site Mix	M25	Anand	183	col	2	4-6-19	7	17.5	395.0	17.6		
										17.5	420.0	18.7	18.2	
										17.5	415.0	18.4		
5394	28-05-2019	Site Mix	M25	Anand	183	col	2	24-6-19	27	25.0	585.0	26.0		
										25.0	580.0	25.8	26.1	
										25.0	595.0	26.4		
5395	30-05-2019	Site Mix	M25	Anand	184	col	2	6-6-19	7	17.5	405.0	18.0		
										17.5	410.0	18.2	18.1	
										17.5	405.0	18.0		
5395	30-05-2019	Site Mix	M25	Anand	184	col	2	26-6-19	27	25.0	585.0	26.0		
										25.0	580.0	25.8	25.8	
										25.0	575.0	25.6		
5396	31-05-2019	Site Mix	M25	Anand	185	col	2	7-6-19	7	17.5	415.0	18.4		
										17.5	420.0	18.7	18.3	
										17.5	400.0	17.8		
5396	31-05-2019	Site Mix	M25	Anand	185	col	2	28-6-19	28	25.0	570.0	25.3		
										25.0	585.0	26.0	25.6	
										25.0	570.0	25.3		

✓
11/7