

DLK

QC - Concrete Cube Testing Report.															
Company:		Nigin Estates													
Project:		Nigin Homes II													
Report for Month:		Nov 18													
Prepared By:		P. Sai Kumar													
Date:		12-01-2019													
No.	Date of casting	Site Mix or B.M.C.	Specified Grade of Concrete	Supplier / Contractor	D. C. No.	Block No. / Foundation No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength (Kilograms)	Tested Strength (N per sq. mm)	Avg. of three tests	Remarks
5318	15-11-2018	Site Mix	M25	Anand		178	col	2	24-11-18	9	17.5 17.5 17.5	410.0 395.0 400.0	18.2 17.6 17.8	17.9	
5318	15-11-2018	Site Mix	M25	Anand		178	col	2	14-12-18	29	25.0 25.0 25.0	570.0 565.0 565.0	24.3 25.1 25.1	25.2	
5319	17-11-2018	Site Mix	M25	Anand		152	col	1	24-11-18	7	17.5 17.5 17.5	400.0 395.0 400.0	17.8 17.6 17.8	17.7	
5319	17-11-2018	Site Mix	M25	Anand		152	col	1	14-12-18	27	25.0 25.0 25.0	565.0 575.0 570.0	25.1 25.6 25.3	25.3	
5320	17-11-2018	Site Mix	M20	Anand		153	slab	3	24-11-18	7	14.0 14.0 14.0	330.0 320.0 325.0	14.2 14.2 14.4	14.4	
5320	17-11-2018	Site Mix	M20	Anand		153	slab	3	14-12-18	27	20.0 20.0 20.0	465.0 460.0 460.0	20.4 20.4 20.4	20.5	
5321	17-11-2018	Site Mix	M20	Anand		156	slab	3	24-11-18	7	14.0 14.0 14.0	325.0 330.0 325.0	14.4 14.7 14.4	14.5	
5321	17-11-2018	Site Mix	M20	Anand		156	slab	3	14-12-18	27	20.0 20.0 20.0	470.0 465.0 465.0	20.6 20.7 20.7	20.7	
5322	19-11-2018	Site Mix	M25	Anand		129	col	1	26-11-18	7	17.5 17.5 17.5	405.0 395.0 400.0	18.0 17.6 17.8	17.8	
5322	19-11-2018	Site Mix	M25	Anand		129	col	1	16-12-18	27	25.0 25.0 25.0	575.0 560.0 565.0	25.6 24.9 25.1	25.2	
5323	19-11-2018	Site Mix	M20	Anand		138	slab	1	26-11-18	7	14.0 14.0 14.0	320.0 320.0 325.0	14.2 14.2 14.4	14.3	

5323	19-11-2018	Site Mix	M20	Anand	138	slab	1	16-12-18	27	20.0	460.0	20.4	
										20.0	455.0	20.2	20.4
										20.0	460.0	20.4	
5324	19-11-2018	Site Mix	M20	Anand	139	slab	1	26-11-18	7	14.0	325.0	14.4	
										14.0	315.0	14.0	14.2
										14.0	320.0	14.2	
5324	19-11-2018	Site Mix	M20	Anand	139	slab	1	16-12-18	27	20.0	465.0	20.7	
										30.0	460.0	20.4	20.6
										30.0	465.0	20.7	
5325	21-11-2018	Site Mix	M20	Anand	179	Ph		29-11-18	8	14.0	320.0	14.2	
										14.0	325.0	14.4	14.4
										14.0	325.0	14.4	
5325	21-11-2018	Site Mix	M20	Anand	179	Ph		19-12-18	28	20.0	460.0	20.4	
										20.0	460.0	20.4	20.5
										20.0	465.0	20.7	
5326	22-11-2018	Site Mix	M20	Anand	170	slab	3	29-11-18	7	14.0	325.0	14.4	
										14.0	330.0	14.7	14.5
										14.0	325.0	14.4	
5326	22-11-2018	Site Mix	M20	Anand	170	slab	3	19-12-18	27	20.0	455.0	20.2	
										20.0	460.0	20.4	20.4
										20.0	465.0	20.7	
5327	23-11-2018	Site Mix	M25	Anand	139	col	2	29-11-18	6	17.5	400.0	17.8	
										17.5	395.0	17.6	17.7
										17.5	400.0	17.8	
5327	23-11-2018	Site Mix	M25	Anand	139	col	2	19-12-18	26	25.0	570.0	25.3	
										25.0	575.0	25.6	25.3
										25.0	565.0	25.1	
5328	23-11-2018	Site Mix	M25	Anand	130	col	1	29-11-18	6	17.5	405.0	18.0	
										17.5	395.0	17.6	17.8
										17.5	400.0	17.8	
5328	23-11-2018	Site Mix	M25	Anand	130	col	1	19-12-18	26	25.0	570.0	25.3	
										25.0	575.0	25.6	25.4
										25.0	570.0	25.3	
5329	24-11-2018	Site Mix	M20	Anand	141	slab	2	2-12-18	8	14.0	320.0	14.2	
										14.0	325.0	14.4	14.3
										14.0	320.0	14.2	
5329	24-11-2018	Site Mix	M20	Anand	141	slab	2	22-12-18	28	20.0	465.0	20.7	
										20.0	470.0	20.9	20.7
										20.0	465.0	20.7	
5330	24-11-2018	Site Mix	M20	Anand	180	Ph		2-12-18	8	14.0	330.0	14.7	
										14.0	320.0	14.2	14.4
										14.0	325.0	14.4	

5330	24-11-2018	Site Mix	M20	Anand	180	Pb		22-12-18	28	20.0	455.0	20.2	
										20.0	450.0	20.0	20.2
										20.0	460.0	20.4	
5331	26-11-2018	Site Mix	M25	Anand	138	col	2	3-12-18	7	17.5	390.0	17.3	
										17.5	395.0	17.6	17.6
										17.5	400.0	17.8	
5331	26-11-2018	Site Mix	M25	Anand	138	col	2	24-12-18	28	25.0	565.0	25.1	
										25.0	575.0	25.6	25.3
										25.0	565.0	25.1	
5332	26-11-2018	Site Mix	M25	Anand	151	col	1	3-12-18	7	17.5	405.0	18.0	
										17.5	395.0	17.6	17.8
										17.5	400.0	17.8	
5332	26-11-2018	Site Mix	M25	Anand	151	col	1	24-12-18	28	25.0	565.0	25.1	
										25.0	570.0	25.3	25.2
										25.0	565.0	25.1	
5333	26-11-2018	Site Mix	M20	Anand	148	slab	2	3-12-18	7	14.0	320.0	14.2	
										14.0	325.0	14.4	14.4
										14.0	330.0	14.7	
5333	26-11-2018	Site Mix	M20	Anand	148	slab	2	24-12-18	28	20.0	455.0	20.2	
										20.0	460.0	20.4	20.4
										20.0	460.0	20.4	
5334	26-11-2018	Site Mix	M20	Anand	172	slab	2	3-12-18	7	14.0	320.0	14.2	
										14.0	325.0	14.4	14.3
										14.0	320.0	14.2	
5334	26-11-2018	Site Mix	M20	Anand	172	slab	2	24-12-18	28	20.0	465.0	20.7	
										20.0	455.0	20.2	20.5
										20.0	465.0	20.7	
5335	27-11-2018	Site Mix	M20	Anand	147	slab	2	3-12-18	6	14.0	330.0	14.7	
										14.0	325.0	14.4	14.5
										14.0	325.0	14.4	
5335	27-11-2018	Site Mix	M20	Anand	147	slab	2	24-12-18	27	20.0	460.0	20.4	
										20.0	455.0	20.2	20.4
										20.0	465.0	20.7	
5336	28-11-2018	Site Mix	M25	Anand	150	col	1	6-12-18	8	17.5	400.0	17.8	
										17.5	395.0	17.6	17.7
										17.5	400.0	17.8	
5336	28-11-2018	Site Mix	M25	Anand	150	col	1	24-12-18	26	25.0	575.0	25.6	
										25.0	570.0	25.3	25.3
										25.0	565.0	25.1	
5337	29-11-2018	Site Mix	M20	Anand	178	slab	2	8-12-18	9	14.0	325.0	14.4	
										14.0	325.0	14.4	14.5
										14.0	330.0	14.7	

5337	20-11-2018	Site Mix	M20	Anand	178	slab	2	26-12-18	27	20.0	465.0	20.7	
										20.0	470.0	20.9	20.7
										20.0	460.0	20.4	
5338	30-11-2018	Site Mix	M20	Anand	177	slab	1	8-12-18	8	14.0	320.0	14.2	
										14.0	325.0	14.4	14.3
										14.0	320.0	14.2	
5338	30-11-2018	Site Mix	M20	Anand	177	slab	1	26-12-18	26	20.0	465.0	20.7	
										20.0	470.0	20.9	20.6
										20.0	455.0	20.3	
5339	30-11-2018	Site Mix	M20	Anand	181	Ph		8-12-18	8	14.0	320.0	14.2	
										14.0	320.0	14.2	14.3
										14.0	325.0	14.4	
5339	30-11-2018	Site Mix	M20	Anand	181	Ph		26-12-18	26	20.0	455.0	20.2	
										20.0	460.0	20.4	20.4
										20.0	465.0	20.7	
5340	30-11-2018	Site Mix	M25	Anand	149	col	1	8-12-18	8	17.5	400.0	17.8	
										17.5	395.0	17.6	17.8
										17.5	405.0	18.0	
5340	30-11-2018	Site Mix	M25	Anand	149	col	1	26-12-18	26	25.0	575.0	25.6	
										25.0	570.0	25.3	25.3
										25.0	565.0	25.1	
5341	05-12-2018	Site Mix	M20	Anand	139	slab	2	12-12-18	5	14.0	325.0	14.4	
										14.0	325.0	14.4	14.5
										14.0	330.0	14.7	
5341	05-12-2018	Site Mix	M20	Anand	139	slab	2	2-1-19	28	20.0	465.0	20.7	
										20.0	455.0	20.2	20.4
										20.0	460.0	20.4	
5342	06-12-2018	Site Mix	M25	Anand	131	col	1	12-12-18	6	17.5	395.0	17.6	
										17.5	395.0	17.6	17.7
										17.5	405.0	18.0	
5342	06-12-2018	Site Mix	M25	Anand	131	col	1	2-1-19	27	25.0	565.0	25.1	
										25.0	570.0	25.3	25.2
										25.0	565.0	25.1	
5344	10-12-2018	Site Mix	M25	Anand	177	col	2	17-12-18	7	17.5	405.0	18.0	
										17.5	400.0	17.8	17.9
										17.5	405.0	18.0	
5344	10-12-2018	Site Mix	M25	Anand	177	col	2	7-1-19	28	25.0	570.0	25.3	
										25.0	565.0	25.1	25.3
										25.0	575.0	25.6	
5345	11-12-2018	Site Mix	M20	Anand	185	footing		17-12-18	6	14.0	320.0	14.2	
										14.0	315.0	14.0	14.2
										14.0	325.0	14.4	

5345	11-12-2018	Site Mix	M20	Anand	185	footing	7 1-19	27	20.0	455.0	20.2	
									20.0	460.0	20.4	20.4
									20.0	460.0	20.4	
5346	13-12-2018	Site Mix	M20	Anand	129	slab	1 20-12-18	7	14.0	320.0	14.2	
									14.0	325.0	14.4	14.4
									14.0	325.0	14.4	
5346	13-12-2018	Site Mix	M20	Anand	129	slab	1 9 1-19	27	20.0	465.0	20.7	
									20.0	460.0	20.4	20.6
									20.0	465.0	20.7	
5347	13-12-2018	Site Mix	M20	Anand	130	slab	1 20-12-18	5	14.0	325.0	14.4	
									14.0	325.0	14.4	14.3
									14.0	315.0	14.0	
5347	13-12-2018	Site Mix	M20	Anand	130	slab	1 9 1-19	27	20.0	465.0	20.7	
									20.0	460.0	20.4	20.7
									20.0	470.0	20.9	
5348	14-12-2018	Site Mix	M25	Anand	179	col	1 22-12-18	8	17.5	405.0	18.0	
									17.5	400.0	17.8	17.9
									17.5	405.0	18.0	
5348	14-12-2018	Site Mix	M25	Anand	179	col	1 11-1-19	28	25.0	575.0	25.6	
									25.0	570.0	25.3	25.3
									25.0	565.0	25.1	