

aruna@modiproperties.com

From: <sohammodi@modiproperties.com>
 Date: 06-08-2018 8:28 AM
 To: <aruna@modiproperties.com>
 Attach: cable routing.pdf
 Subject: FW: Reg. Electrical Cable routing of NE P-II Design

Print

Regards,

Soham Modi

Managing Director | +91 40 6633 5556 | sohammodi@modiproperties.com

Don't just buy a flat / villa! Buy a great lifestyle!

Affordable flats / villas in gated communities.

Modi Properties Pvt. Ltd. | www.modiproperties.com

5-4-187/ 3 & 4, M G Road, Sec'bad -03 | Ph: +91 40 6633 5551

From: Nilgiri Estates <nilgiriestate@modiproperties.com>

Sent: 04 08 2018 12:59 PM

To: Soham Modi <sohammodi@modiproperties.com>

Cc: madhav@modiproperties.com; plans@modiproperties.com

Subject: Reg. Electrical Cable routing of NE P-II Design

Respected Sir,

As per your instructions to discuss with Electrical contractor person (Mr. Dinakar Mob: 9000436869)

1. As per drawing 240 Sq mm LT Cable & 185 Sq mm cable is required only from Transformer to Panel Room (which is below the Transformer room)

2. As per Drawing 50 Sq mm Cable From Panel room to FB-13 (Villa No: 100) & 70 Sq mm cable from Panel room to FB-15 (Villa No: 111).
But at Site CC pipe laying not completed in between V100 to V111.3. Hence Contractor is requesting For laying 70 Sq mm Cable from New Panel Room to FB-12 (At V 99) But In Drawing, cable is from Club House Old panel room P-I.
(It is Difficulty to lay Cable from Old Panel Room by Breakage of CC road)


4. 70 Sq mm Cable from Panel room to Fb -14 Through Front Row (CC pipe laying not completed in between V100 to V111).

5. Giving Looping 50 Sq mm Cable From FB-12 To FB-13 & FB-14 to FB-15, CC Pipes already laid in Front Line from V 80 to 99.

Please issue New Drawing, at present we have to give possession from V 81 to 99.

Note: Contractor is Requesting cable laying with CC Pipes from panel room to FB giving Manholes at 15m Interval since it is 70 Sq mm Cable & 50 Sqmm cable at South side TOT LOT area for easy maintainece purpose

06-08-2018



Scanned by CamScanner