

QC - Concrete Cube Testing Report.															
Company:		MCMET													
Project:		Manilal Modi Memorial Hospital													
Report for Month:		May to Aug-2020													
Prepared By:		QC Team													
Date:		03-09-2020													
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
19100	07-03-2020	RMC	M20	Homeline		1	Footing		14-3-20	7	14.0	335.0	14.9		
											14.0	330.0	14.7	14.7	
											14.0	330.0	14.7		
19101	14-03-2020	RMC	M20	Homeline		1	Footing		20/3/2020	6	14.0	325.0	14.4		
											14.0	330.0	14.7	14.6	
											14.0	330.0	14.7		