

QC - Concrete Cube Testing Report.															
Company:		SOVLLP													
Project:		SOV													
Report for Month:		Jul&Aug-20													
Prepared By:		QC Team													
Date:		05-10-2020													
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
7331	10-08-2020	RMC	M20	Scpl		133	Footings		19-8-20	9	14.0	325.0	14.4		
											14.0	325.0	14.4	14.5	
											14.0	330.0	14.7		
7331	10-08-2020	RMC	M20	Scpl		133	Footings		8-9-20	29	20.0	470.0	20.9		
											20.0	475.0	21.1	20.9	
											20.0	465.0	20.7		
7332	11-08-2020	RMC	M20	Rcpl		117	Footings		19-8-20	8	14.0	320.0	14.2		
											14.0	325.0	14.4	14.3	
											14.0	320.0	14.2		
7332	11-08-2020	RMC	M20	Rcpl		117	Footings		8-9-20	28	20.0	465.0	20.7		
											20.0	470.0	20.9	20.7	
											20.0	465.0	20.7		
7333	11-08-2020	RMC	M20	Rcpl		118	Footings		19-8-20	8	14.0	325.0	14.4		
											14.0	325.0	14.4	14.5	
											14.0	330.0	14.7		
7333	11-08-2020	RMC	M20	Rcpl		118	Footings		8-9-20	28	20.0	475.0	21.1		
											20.0	475.0	21.1	21.2	
											20.0	480.0	21.3		
7334	12-08-2020	RMC	M20	Rcpl		104	Plinth		19-8-20	7	14.0	325.0	14.4		
											14.0	320.0	14.2	14.3	
											14.0	320.0	14.2		
7334	12-08-2020	RMC	M20	Rcpl		104	Plinth		8-9-20	27	20.0	460.0	20.4		
											20.0	465.0	20.7	20.6	
											20.0	465.0	20.7		

[illegible]