

QC - Concrete Cube Testing Report.															
Company:		GVRC													
Project:		Innopolis													
Report for Month:		Aug & Sep-20													
Prepared By:		QC Team													
Date:		05-10-2020													
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
14127	01-06-2020	RMC	M30	Isaaq		2727	COL	2	8-6-20	7	21.5	490.0	21.8		
											21.5	495.0	22.0	21.9	
											21.5	495.0	22.0		
14127	01-06-2020	RMC	M30	Isaaq		2727	COL	2	30-6-20	29	30.0	695.0	30.9		
											30.0	695.0	30.9	30.8	
											30.0	690.0	30.7		
14128	03-06-2020	RMC	M30	Isaaq		2727	COL	2	10-6-20	7	21.5	500.0	22.2		
											21.5	495.0	22.0	22.1	
											21.5	495.0	22.0		
14128	03-06-2020	RMC	M30	Isaaq		2727	COL	2	30-6-20	27	30.0	700.0	31.1		
											30.0	705.0	31.3	31.2	
											30.0	700.0	31.1		
14129	06-06-2020	RMC	M30	Isaaq		2727	COL	2	13-6-20	7	21.5	490.0	21.8		
											21.5	490.0	21.8	21.9	
											21.5	495.0	22.0		
14129	06-06-2020	RMC	M30	Isaaq		2727	COL	2	4-7-20	28	30.0	700.0	31.1		
											30.0	705.0	31.3	31.1	
											30.0	695.0	30.9		
14130	08-06-2020	RMC	M25	Pointek		4545	Footing		15-6-20	7	17.5	405.0	18.0		
											17.5	405.0	18.0	17.9	
											17.5	400.0	17.8		
14130	08-06-2020	RMC	M25	Pointek		4545	Footing		6-7-20	28	25.0	585.0	26.0		
											25.0	585.0	26.0	26.1	
											25.0	590.0	26.2		

14131	10-06-2020	RMC	M30	Isaaq	2727	COL	3	17-6-20	7	21.5	490.0	21.8		
										21.5	490.0	21.8	21.9	
										21.5	495.0	22.0		
14131	10-06-2020	RMC	M30	Isaaq	2727	COL	3	10-7-20	30	30.0	695.0	30.9		
										30.0	695.0	30.9	30.8	
										30.0	690.0	30.7		
14132	24-06-2020	RMC	M30	Isaaq	2727	COL	3	30-6-20	6	21.5	495.0	22.0		
										21.5	495.0	22.0	22.1	
										21.5	500.0	22.2		
14132	24-06-2020	RMC	M30	Isaaq	2727	COL	3	21-7-20	27	30.0	700.0	31.1		
										30.0	705.0	31.3	31.2	
										30.0	700.0	31.1		
14133	27-06-2020	RMC	M30	Isaaq	2727	COL	3	4-7-20	7	21.5	495.0	22.0		
										21.5	495.0	22.0	21.9	
										21.5	490.0	21.8		
14133	27-06-2020	RMC	M30	Isaaq	2727	COL	3	27-7-20	30	30.0	690.0	30.7		
										30.0	695.0	30.9	30.9	
										30.0	700.0	31.1		
14134	29-06-2020	RMC	M30	Isaaq	2727	COL	3	4-7-20	5	21.5	500.0	22.2		
										21.5	495.0	22.0	22.1	
										21.5	495.0	22.0		
14134	29-06-2020	RMC	M30	Isaaq	2727	COL	3	27-7-20	28	30.0	700.0	31.1		
										30.0	705.0	31.3	31.2	
										30.0	700.0	31.1		
14135	06-07-2020	RMC	M30	Isaaq	2727	COL	3	13-7-20	7	21.5	495.0	22.0		
										21.5	490.0	21.8	21.8	
										21.5	485.0	21.6		
14135	06-07-2020	RMC	M30	Isaaq	2727	COL	3	3-8-20	28	30.0	690.0	30.7		
										30.0	700.0	31.1	30.9	
										30.0	695.0	30.9		

14136	14-07-2020	RMC	M25	Pointek		4545	Footing		21-7-20	7	17.5	405.0	18.0		
											17.5	405.0	18.0	17.9	
											17.5	400.0	17.8		
14136	14-07-2020	RMC	M25	Pointek		4545	Footing		12-8-20	29	25.0	585.0	26.0		
											25.0	585.0	26.0	25.9	
											25.0	580.0	25.8		
14137	31-07-2020	RMC	M30	Isaaq		2727	COL	3	7-8-20	7	21.5	495.0	22.0		
											21.5	490.0	21.8	21.9	
											21.5	495.0	22.0		
14137	31-07-2020	RMC	M30	Isaaq		2727	COL	3	28-8-20	28	30.0	700.0	31.1		
											30.0	705.0	31.3	31.2	
											30.0	700.0	31.1		
14138	31-07-2020	RMC	M25	Shankar		5600E	Footing		7-8-20	7	17.5	405.0	18.0		
											17.5	405.0	18.0	17.9	
											17.5	400.0	17.8		
14138	31-07-2020	RMC	M25	Shankar		5600E	Footing		28-8-20	28	25.0	585.0	26.0		
											25.0	575.0	25.6	25.8	
											25.0	580.0	25.8		
14139	06-08-2020	RMC	M30	Isaaq		2727	lift	3	14-8-20	8	21.5	490.0	21.8		
											21.5	495.0	22.0	21.8	
											21.5	485.0	21.6		
14139	06-08-2020	RMC	M30	Isaaq		2727	lift	3	3-9-20	28	30.0	695.0	30.9		
											30.0	690.0	30.7	30.8	
											30.0	695.0	30.9		
14140	12-08-2020	RMC	M25	Shankar		Compound w	Footing		20-8-20	8	17.5	405.0	18.0		
											17.5	405.0	18.0	17.9	
											17.5	400.0	17.8		
14140	12-08-2020	RMC	M25	Shankar		Compound w	Footing		8-9-20	27	25.0	575.0	25.6		
											25.0	580.0	25.8	25.7	
											25.0	580.0	25.8		
14141	13-08-2020	RMC	M25	Pointek		4545	Footing		20-8-20	7	17.5	405.0	18.0		
											17.5	400.0	17.8	17.8	
											17.5	395.0	17.6		
14141	13-08-2020	RMC	M25	Pointek		4545	Footing		8-9-20	26	25.0	575.0	25.6		
											25.0	575.0	25.6	25.6	

											25.0	580.0	25.8		
--	--	--	--	--	--	--	--	--	--	--	------	-------	------	--	--

14142	25-08-2020	RMC	M25	Shankar	Compound w	wall	2-9-20	8	17.5	400.0	17.8		
									17.5	400.0	17.8	17.7	
									17.5	395.0	17.6		
14142	25-08-2020	RMC	M25	Shankar	Compound w	wall	23-9-20	29	25.0	575.0	25.6		
									25.0	570.0	25.3	25.5	
									25.0	575.0	25.6		
14143	25-08-2020	RMC	M25	Pointek	4545	Footing	31-8-20	6	17.5	405.0	18.0		
									17.5	405.0	18.0	17.9	
									17.5	400.0	17.8		
14143	25-08-2020	RMC	M25	Pointek	4545	Footing	22-9-20	28	25.0	580.0	25.8		
									25.0	575.0	25.6	25.7	
									25.0	580.0	25.8		
14144	31-08-2020	RMC	M25	Shankar	5600E	Plinth	8-9-20	8	17.5	395.0	17.6		
									17.5	400.0	17.8	17.7	
									17.5	400.0	17.8		
14144	31-08-2020	RMC	M25	Shankar	5600E	Plinth	29-9-20	29	25.0	575.0	25.6		
									25.0	575.0	25.6	25.5	
									25.0	570.0	25.3		
14145	01-09-2020	RMC	M25	Pointek	4545	Footing	8-9-20	7	17.5	405.0	18.0		
									17.5	395.0	17.6	17.8	
									17.5	400.0	17.8		
14145	01-09-2020	RMC	M25	Pointek	4545	Footing	29-9-20	28	25.0	585.0	26.0		
									25.0	580.0	25.8	25.9	
									25.0	580.0	25.8		
14146	02-09-2020	RMC	M25	Shankar	5600E	Plinth	8-9-20	6	17.5	395.0	17.6		
									17.5	395.0	17.6	17.6	
									17.5	400.0	17.8		
14146	02-09-2020	RMC	M25	Shankar	5600E	Plinth	29-9-20	27	25.0	580.0	25.8		
									25.0	575.0	25.6	25.6	
									25.0	570.0	25.3		