

QC - Concrete Cube Testing Report															
Company:		M/MR(LLP)													
Project:		GHT													
Report for Month:		Aug & Sep-2020													
Prepared By:		QC Team													
Date:		08-10-2020													
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No./ Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength in Kilo-Newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
18112	12-08-2020	Site Mix	M20	HomeLine		B	Ramp	1	19-8-20	7	14.0	320.0	14.2	14.1	
											14.0	320.0	14.2		
											14.0	315.0	14.0		
18112	12-08-2020	Site Mix	M20	HomeLine		B	Ramp	1	9-9-20	28	20.0	450.0	20.0	20.3	
											20.0	460.0	20.4		
											20.0	460.0	20.4		
18113	20-08-2020	Site Mix	M25	HomeLine		Bldg	Col	1	28-8-20	8	17.5	395.0	17.6		
											17.5	400.0	17.8	17.7	
											17.5	400.0	17.8		
14113	20-08-2020	Site Mix	M25	HomeLine		Bldg	Col	1	17-9-20	28	25.0	565.0	25.1		
											25.0	570.0	25.3	25.3	
											25.0	570.0	25.3		
18114	31-08-2020	RMC	M20	HomeLine		B	Slab	1	7-9-20	7	14.0	320.0	14.2	14.3	
											14.0	320.0	14.2		
											14.0	325.0	14.4		
18114	31-08-2020	RMC	M20	HomeLine		B	Slab	1	29-9-20	29	20.0	460.0	20.4		
											20.0	470.0	20.9	20.7	
											20.0	465.0	20.7		
18115	04-09-2020	RMC	M20	HomeLine		B	Footings		10-9-20	7	14.0	320.0	14.2		
											14.0	325.0	14.4	14.4	
											14.0	325.0	14.4		
18115	04-09-2020	RMC	M20	HomeLine		B	Footings		1-10-20	27	20.0	470.0	20.5		
											20.0	465.0	20.7	20.8	
											20.0	470.0	20.5		
18116	08-09-2020	RMC	M25	HomeLine		B	Col	2	16-9-20	8	21.5	535.0	21.8		
											21.5	540.0	24.0	23.5	
											21.5	540.0	24.0		
18116	08-09-2020	RMC	M25	HomeLine		B	Col	2	7-10-20	29	35.0	810.0	36.0	35.9	
											35.0	810.0	36.0		
											35.0	805.0	35.8		
18117	09-09-2020	Site Mix	M25	HomeLine		B	Col	2	16-9-20	7	17.5	395.0	17.6		
											17.5	400.0	17.8	17.8	
											17.5	405.0	18.0		
18117	09-09-2020	Site Mix	M25	HomeLine		B	Col	2	7-10-20	28	25.0	570.0	25.3		
											25.0	575.0	25.6	25.4	
											25.0	570.0	25.3		

APPROVED BY

10 OCT 2020

A. SURESH
PROJECT MANAGER