


aruna@modiproperties.com

From: "BnC estates" <bnc@modiproperties.com>
Date: 30-10-2017 4:19 PM
To: "Soham Sir" <sohammodi@modiproperties.com>
Cc: "Aruna-Admin" <aruna@modiproperties.com>; "Haribabu Asst Manager-purchase" <haribabu@modiproperties.com>; "BnC Estates" <bnc@modiproperties.com>
Attach: Lift complaints details.xls
Subject: OTIS Passenger Lifts breakdown complaint details -reg

To,
MD Sir,

Please find the attachment of OTIS Passenger Lifts complaints details.

Total - 34 complaints we made w.e.f April.17 to till day while breakdown of Lifts in A & B - Blocks.

As per MD sir instructions the above mail forwarding.

Regards,

Ravi

30-10-2017

OTIS Lifts Complaints monthwise details at Mayflower Grande.				
Prepared by		Ravi		
Date		30.10.17		
S.No	Block	Month	No's Complaints	Remarks
1	A & B	April.2017	6	
2	A & B	May.2017	2	
3	A & B	June.2017	3	
4	A & B	July.2017	4	
5	A & B	Aug.2017	9	
6	A & B	Sep.2017	4	
7	A & B	Oct.2017	6	
			34	

Company	BNC Estates				
Project Name	MFG				
Prepared by	Ravi				
Date	30.10.17				
OTIS Passengers lifts breakdown details at Mayflower Grande.					
S.No	Block	Complaint Date	Complaint No	Description	Remarks
1	A	04-04-2017	2559168	Light & Fan not working in A - Block lift inside	
2	A	04-07-2017	2562240	01 Lift is not working in A - Block	
3	B	04-07-2017	2562242	01 Lift is not working in B -Block	
4	A	18-4-2017	2573823	01 Lift car door is not closing properly	
5	B	19-4-2017	2574962	01 Lifts in not working in B-Block	
6	A	27-4-2017	2583345	01 Lifts in not working in A-Block	
7	A	05-11-2017	2596543	01 Lift is Frequently getting struck in 7th floor & doors are not closing properly.	
8	A	23-5-2017	26095401	01 Lift is not working as frequently getting breakdown in A - block Lift.	
9	B	06-08-2017	2659632	01 Lifts sensor not working in B - Block.	
10	A	06-12-2017	2629247	01 Lift is breakdown in 8th Floor	
11	A	19-6-2017	2636527	01 Lift is not working and it is breakdown in 5th Floor.	
12	B	07-07-2017	2655753	01 Lift is not working in B - Block	
13	A	13-7-2017	2662173	Customers are struck inside of A - Block lift.	
14	A	29-7-2017	2679286	01 Lift is not working in A - Block	
15	A	29-7-2017	2679374	A - Block 01 lift breakdown at 5th floor and doors not closing properly.	
16	B	08-05-2017	2686407	B - Block 01 lift sensor not working.	
17	A	08-11-2017	2686409	A - Block 1 lift frequently getting breakdown in 5th Floor	
18	B	08-11-2017	2691775	B - Bloc 01 Lift sensor not working.	
19	A & B	08-12-2017	2691776	Both blocks lifts got breakdown.	
20	A	08-12-2017	2693353	01 Lift is not working in A - Block	
21	A	15-8-2017	2699277	01 Lift is Frequently getting struck in 7th floor & doors are not closing properly.	
22	B	19/8/17	2699778	B - Bloc 01 Lift sensor not working.	
23	A	22-8-2017	2702430	A - Block 01 lift breakdown at 5th floor and doors not closing properly.	
24	B	27-8-2017	2707885	B - Block 01 lift sensor not working.	
25	B	09-05-2017	2717711	B - Block 01 lift sensor not working.	
26	A	09-09-2017	2722051	01 Lift is frequently getting breakdown at 5th Floor	
27	A	09-11-2017	2724027	01 Lift is frequently getting breakdown at 5th Floor	
28	B	27-9-2017	2739187	B - Block 01 lift sensor not working.	
29	A	10-01-2017	2742476	01 Lift car door is not closing properly	
30	B	10-10-2017	2752071	B - Block 01 lift sensor not working.	
31	B	13-10-2017	2754765	B - Block 01 lift sensor not working.	
32	A	15-10-2017	2757046	01 Lift is breakdown in 5th Floor.	
33	A	25-10-2017	2765901	01 Lift is Frequently getting struck in 8th floor & doors are not closing properly.	
34	A	30-10-2017	2771402	01 lift is not working in A -Block..	