

QC - Concrete Cube Testing Report															
Company:	Alben Developers			Project:	MGA			Report for Month:	Oct & Nov-2020			Prepared By:	QC Team		
Date:	08-12-2020														
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilograms	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
17116	07-07-2020	RMC	M20	Swarn		1	Slab(1,2,5,6)	3	15-7-20	8	14.0	325.0	14.4	14.4	
											14.0	320.0	14.2		
17116	07-07-2020	RMC	M20	Swarn		1	Slab(1,2,5,6)	3	4-8-20	28	20.0	465.0	20.7	20.8	
											20.0	470.0	20.9		
17117	07-07-2020	RMC	M20	Swarn		1	Slab(3&4)	4	15-7-20	8	14.0	325.0	14.4	14.4	
											14.0	320.0	14.2		
17117	07-07-2020	RMC	M20	Swarn		1	Slab(3&4)	4	4-8-20	28	20.0	465.0	20.7	20.8	
											20.0	470.0	20.9		
17118	31-07-2020	Site Mix	M25	Yadav		1	Col(1,2,5,6)	4	7-8-20	7	17.5	405.0	18.0	17.8	
											17.5	400.0	17.8		
17118	31-07-2020	Site Mix	M25	Yadav		1	Col(1,2,5,6)	4	27-8-20	27	25.0	580.0	25.8	25.6	
											25.0	575.0	25.6	25.6	
17119	01-08-2020	Site Mix	M25	Yadav		1	Col(3,4)	5	7-8-20	6	17.5	395.0	17.6	17.6	
											17.5	400.0	17.8		
17119	01-08-2020	Site Mix	M25	Yadav		1	Col(3,4)	5	27-8-20	26	25.0	570.0	25.3	25.4	
											25.0	575.0	25.6	25.6	
17120	11-09-2020	RMC	M20	Swarn		1	Slab(1,2,5,6)	4	18-9-20	7	14.0	325.0	14.4	14.3	
											14.0	320.0	14.2		
17120	11-09-2020	RMC	M20	Swarn		1	Slab(1,2,5,6)	4	9-10-20	28	20.0	465.0	20.7	20.7	
											20.0	470.0	20.9		
17121	19-09-2020	Site Mix	M25	Yadav		1	Col(1,2,5,6)	5	26-9-20	7	17.5	400.0	17.8	17.7	
											17.5	395.0	17.6	17.6	
17121	19-09-2020	Site Mix	M25	Yadav		1	Col(1,2,5,6)	5	17-10-20	28	25.0	575.0	25.6	25.5	
											25.0	570.0	25.3		
17122	30-09-2020	RMC	M20	Swarn		1	Slab(3&4)	5	8-10-20	8	14.0	325.0	14.4	14.4	
											14.0	320.0	14.2		
17122	30-09-2020	RMC	M20	Swarn		1	Slab(3&4)	5	29-10-20	29	20.0	465.0	20.7	20.9	
											20.0	475.0	21.1	20.9	

APPROVED BY

31 DEC 2020

507

APPROVED BY

31 DEC 2020

T. MADHU
PROJECT MANAGER B.R.G.V.

For

Md. Asad May