

QC - Concrete Cube Testing Report
 Company: MCAET
 Project: Mahatma Memorial Hospital
 Report for Month: Oct & Nov-2020
 Prepared By: QC Team
 Date: 08-12-2020

S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
19102	18/6/2020	RMC	M20	HomeLine		1	Footing		25/6/2020	7	14.0	325.0	14.4	14.5	
											14.0	325.0	14.4		
											14.0	330.0	14.7		
19102	18/6/2020	RMC	M20	HomeLine		1	Footing		16/7/2020	28	20.0	475.0	21.1	21.2	
											20.0	475.0	21.1		
											20.0	480.0	21.3		
19103	26/6/2020	RMC	M20	HomeLine		1	Footing		4-7-20	8	14.0	325.0	14.4	14.4	
											14.0	325.0	14.4		
19103	26/6/2020	RMC	M20	HomeLine		1	Footing		25-7-20	29	20.0	465.0	20.7	20.9	
											20.0	475.0	21.1		
											20.0	470.0	20.9		
19104	22-07-2020	Site Mix	M20	HomeLine		1	Plumb		30-7-20	8	14.0	315.0	14.0	14.2	
											14.0	320.0	14.2		
											14.0	325.0	14.4		
19104	22-07-2020	Site Mix	M20	HomeLine		1	Plumb		20-8-20	29	20.0	465.0	20.7	20.6	
											20.0	465.0	20.7		
											20.0	460.0	20.4		
19105	12-08-2020	Site Mix	M25	HomeLine		1	Col		19-8-20	7	17.5	395.0	17.6	17.7	
											17.5	400.0	17.8		
19105	12-08-2020	Site Mix	M25	HomeLine		1	Col		8-9-20	27	25.0	575.0	25.6	25.5	
											25.0	575.0	25.6		
											25.0	570.0	25.3		
19106	16-09-2020	Site Mix	M25	HomeLine		1	Slab		22-9-20	6	17.5	405.0	18.0	18.1	
											17.5	410.0	18.2		
											17.5	410.0	18.2		
19106	16-09-2020	Site Mix	M25	HomeLine		1	Slab		14-10-20	28	25.0	575.0	25.6	25.8	
											25.0	585.0	26.0		
											25.0	580.0	25.8		
19107	22-09-2020	Site Mix	M25	HomeLine		1	Col		29-9-20	7	17.5	405.0	18.0	17.9	
											17.5	400.0	17.8		
											17.5	400.0	17.8		
19107	22-09-2020	Site Mix	M25	HomeLine		1	Col		20-10-20	28	25.0	575.0	25.6	25.6	
											25.0	575.0	25.6		
											25.0	580.0	25.8		
19108	01-10-2020	Site Mix	M25	HomeLine		1	Slab		8-10-20	7	17.5	395.0	17.6	17.7	
											17.5	400.0	17.8		
											17.5	400.0	17.8		
19108	01-10-2020	Site Mix	M25	HomeLine		1	Slab		38-10-20	27	25.0	570.0	25.3	25.4	
											25.0	575.0	25.6		
											25.0	570.0	25.3		

APPROVED BY

31 DEC 2020

T. MADHU
PROJECT MANAGER B.R.G.V.

for
M.D. Kalyan