

QC - Concrete Cube Testing Report

Company: GVRRC

Project: Innopolis

Report for Month: Nov-20

Prepared By: QC Team

Date: 07-12-2020

S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
14147	12-09-2020	RMC	M25	Shankar		5600E	COL	1	19-9-20	7	17.5	400.0	17.8	17.9	
											17.5	405.0	18.0		
											17.5	400.0	17.8		
14147	12-09-2020	RMC	M25	Shankar		5600E	COL	1	10-10-20	28	25.0	580.0	25.8	25.9	
											25.0	585.0	26.0		
											25.0	580.0	25.8		
14148	21-09-2020	RMC	M25	Shankar		5600E	C/W Slab		28-9-20	7	17.5	395.0	17.6	17.8	
											17.5	400.0	17.8	17.8	
											17.5	405.0	18.0		
14148	21-09-2020	RMC	M25	Shankar		5600E	C/W Slab		20-10-20	29	25.0	580.0	25.8	25.6	
											25.0	575.0	25.6	25.6	
											25.0	575.0	25.6		
14149	25-09-2020	RMC	M25	Pointeck		4545	Footings		3-10-20	8	17.5	405.0	18.0	17.7	
											17.5	400.0	17.8		
											17.5	390.0	17.3		
14149	25-09-2020	RMC	M25	Pointeck		4545	Footings		24-10-20	29	25.0	605.0	26.9	26.6	
											25.0	600.0	26.7	26.6	
											25.0	590.0	26.2		
14150	02-09-2020	RMC	M25	Shankar		5600E	Slab	1	10-9-20	8	17.5	395.0	17.6	17.5	
											17.5	395.0	17.6		
											17.5	390.0	17.3		
14150	02-09-2020	RMC	M25	Shankar		5600-E	Slab	1	30-9-20	28	25.0	610.0	27.1	26.7	
											25.0	595.0	26.4	26.7	
											25.0	595.0	26.4		

APPROVED BY

05 JAN 2021

G. Venkatesh
Project Manager

14151	04-10-2020	RMC	M25	Poinceck	4545	Footings		10-10-20	6	17.5	405.0	18.0		
										17.5	390.0	17.3	17.8	
										17.5	405.0	18.0		
14151	04-10-2020	RMC	M25	Poinceck	4545	Footings		2-11-20	29	25.0	605.0	26.9		
										25.0	590.0	26.2	26.7	
										25.0	605.0	26.9		
14152	07-10-2020	RMC	M25	Shankar	5600E	COL	2	16-10-20	9	17.5	400.0	17.8		
										17.5	405.0	18.0	17.9	
										17.5	400.0	17.8		
14152	07-10-2020	RMC	M25	Shankar	5600E	COL	2	4-11-20	28	25.0	595.0	26.4		
										25.0	595.0	26.4	26.2	
										25.0	580.0	25.8		
14153	08-10-2020	RMC	M25	Poinceck	4545	Footings		16-10-20	8	17.5	410.0	18.2		
										17.5	395.0	17.6	17.8	
										17.5	395.0	17.6		
14153	08-10-2020	RMC	M25	Poinceck	4545	Footings		7-11-20	30	25.0	610.0	27.1		
										25.0	595.0	26.4	26.6	
										25.0	590.0	26.2		
14154	08-10-2020	RMC	M25	Shankar	5600E	COL	2	16-10-20	8	17.5	395.0	17.6		
										17.5	390.0	17.3	17.3	
										17.5	380.0	16.9		
14154	08-10-2020	RMC	M25	Shankar	5600E	COL	2	7-11-20	30	25.0	595.0	26.4		
										25.0	590.0	26.2	26.1	
										25.0	580.0	25.8		
14155	17-10-2020	RMC	M25	Ishag	2727	Slab	3	24-10-20	7	17.5	410.0	18.2		
										17.5	410.0	18.2	18.1	
										17.5	405.0	18.0		
14155	17-10-2020	RMC	M25	Ishag	2727	Slab	3	14-11-20	28	25.0	595.0	26.4		
										25.0	610.0	27.1	26.9	
										25.0	610.0	27.1		

14156	18-10-2020	RMC	M25	Ishag	2727	Slab	3	24-10-20	6	17.5	405.0	18.0		
										17.5	395.0	17.6	17.8	
										17.5	400.0	17.8		
14156	18-10-2020	RMC	M25	Ishag	2727	Slab	3	16-11-20	29	25.0	605.0	26.9		
										25.0	595.0	26.4	26.7	
										25.0	600.0	26.7		
14157	28-10-2020	RMC	M25	Pointeck	4545	Footings		4-11-20	7	17.5	410.0	18.2		
										17.5	390.0	17.3	17.9	
										17.5	405.0	18.0		
14157	28-10-2020	RMC	M25	Pointeck	4545	Footings		27-11-20	30	25.0	610.0	27.1		
										25.0	590.0	26.2	26.7	
										25.0	605.0	26.9		
14158	31-10-2020	RMC	M25	Shankar	5600-E	Slab	2	7-11-20	7	17.5	395.0	17.6		
										17.5	395.0	17.6	17.6	
										17.5	400.0	17.8		
14158	31-10-2020	RMC	M25	Shankar	5600-E	Slab	2	30-11-20	30	25.0	595.0	26.4		
										25.0	595.0	26.4	26.6	
										25.0	605.0	26.9		

APPROVED BY

05 JAN 2021
G. Venkatesh
Project Manager