

QC - Concrete Cube Testing Report.																		
Company:		MCMET																
Project:		Manilal Modi Memorial Hospital																
Report for Month:		Nov Dec -2020																
Prepared By:		QC Team																
Date:		05-01-2021																
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks			
19109	23-10-2020	RMC	M25	Homeline		1	Slab	2	31-10-20	8	17.5	395.0	17.6					
											17.5	415.0	18.4	18.1				
											17.5	410.0	18.2					
19109	23-10-2020	RMC	M25	Homeline		1	Slab	2	21-11-20	29	25.0	610.0	27.1					
											25.0	615.0	27.3	27.2				
											25.0	610.0	27.1					
19110	02-11-2020	Site Mix	M25	Homeline		1	col	3	10-11-20	8	17.5	405.0	18.0					
											17.5	385.0	17.1	17.6				
											17.5	400.0	17.8					
19110	02-11-2020	Site Mix	M25	Homeline		1	col	3	1-12-20	29	25.0	555.0	24.7					
											25.0	555.0	24.7	24.9	*			
											25.0	570.0	25.3					
19111	02-11-2020	Site Mix	M20	Homeline		1	staircase	3	10-11-20	8	14.0	320.0	14.2					
											14.0	310.0	13.8	14.1				
											14.0	325.0	14.4					
19111	02-11-2020	Site Mix	M20	Homeline		1	staircase	3	1-12-20	29	20.0	455.0	20.2					
											20.0	470.0	20.9	20.4				
											20.0	455.0	20.2					
19112	02-12-2020	RMC	M25	Homeline		1	Slab	3	10-12-20	8	17.5	395.0	17.6					
											17.5	415.0	18.4	18.1				
											17.5	410.0	18.2					
19112	02-12-2020	RMC	M25	Homeline		1	Slab	3	31-12-20	29	25.0	595.0	26.4					
											25.0	595.0	26.4	26.7				
											25.0	615.0	27.3					
19113	10-12-2020	Site Mix	M25	Homeline		1	col	4	19-12-20	9	17.5	405.0	18.0					
											17.5	395.0	17.6	17.8				
											17.5	400.0	17.8					
19114	17-12-2020	Site Mix	M20	Homeline		1	staircase	4	26-12-20	9	14.0	325.0	14.4					
											14.0	315.0	14.0	14.2				
											14.0	320.0	14.2					