

QC - Concrete Cube Testing Report.																
Company:		SOVLLP														
Project:		SOV														
Report for Month:		Nov & Dec -20														
Prepared By:		QC Team														
Date:		07-01-2020														
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks	
7370	24-10-2020	RMC	M20	RCPL		113	Plinth		31-10-20	7	14.0	320.0	14.2			
											14.0	320.0	14.2	14.3		
											14.0	325.0	14.4			
7370	24-10-2020	RMC	M20	RCPL		113	Plinth		21-11-20	28	20.0	465.0	20.7			
											20.0	465.0	20.7	20.7		
											20.0	470.0	20.9			
7371	31-10-2020	RMC	M25	RCPL		105	Col	1	9-11-20	9	17.5	400.0	17.8			
											17.5	405.0	18.0	17.9		
											17.5	400.0	17.8			
7371	31-10-2020	RMC	M25	RCPL		105	Col	1	28-11-20	28	25.0	575.0	25.6			
											25.0	580.0	25.8	25.7		
											25.0	580.0	25.8			
7372	03-11-2020	RMC	M20	SCPL		127	Slab	2	10-11-20	7	14.0	320.0	14.2			
											14.0	315.0	14.0	14.2		
											14.0	325.0	14.4			
7372	03-11-2020	RMC	M20	SCPL		127	Slab	2	30-11-20	27	20.0	465.0	20.7			
											20.0	460.0	20.4	20.6		
											20.0	465.0	20.7			
7373	07-11-2020	RMC	M20	RCPL		102	Slab	1	14-11-20	7	14.0	325.0	14.4			
											14.0	325.0	14.4	14.3		
											14.0	315.0	14.0			
7373	07-11-2020	RMC	M20	RCPL		102	Slab	1	5-12-20	28	20.0	455.0	20.2			
											20.0	465.0	20.7	20.5		
											20.0	465.0	20.7			
7374	07-11-2020	RMC	M20	RCPL		104	Slab	1	14-11-20	7	14.0	335.0	14.9			
											14.0	330.0	14.7	14.6		
											14.0	320.0	14.2			
7374	07-11-2020	RMC	M20	RCPL		104	Slab	1	5-12-20	28	20.0	460.0	20.4			
											20.0	460.0	20.4	20.4		
											20.0	455.0	20.2			
7375	09-11-2020	RMC	M25	SCPL		131	Col	3	18-11-20	9	17.5	405.0	18.0			
											17.5	410.0	18.2	18.1		
											17.5	410.0	18.2			
7375	09-11-2020	RMC	M25	SCPL		131	Col	3	8-12-20	29	25.0	585.0	26.0			
											25.0	585.0	26.0	25.8		
											25.0	570.0	25.3			

7376	10-11-2020	RMC	M25	SCPL		126	Col	2	18-11-20	8	17.5	410.0	18.2			
											17.5	405.0	18.0	17.9		
											17.5	395.0	17.6			
7376	10-11-2020	RMC	M25	SCPL		126	Col	2	8-12-20	28	25.0	575.0	25.6			
											25.0	570.0	25.3	25.6		
											25.0	585.0	26.0			
7377	11-11-2020	RMC	M25	SCPL		127	Col	3	18-11-20	7	17.5	390.0	17.3			
											17.5	395.0	17.6	17.4		
											17.5	390.0	17.3			
7377	11-11-2020	RMC	M25	SCPL		127	Col	3	8-12-20	27	25.0	595.0	26.4			
											25.0	595.0	26.4	25.9		
											25.0	560.0	24.9			
7378	13-11-2020	RMC	M20	RCPL		101	Slab	1	21-11-20	8	14.0	325.0	14.4			
											14.0	335.0	14.9	14.3		
											14.0	305.0	13.6			
7378	13-11-2020	RMC	M20	RCPL		101	Slab	1	12-12-20	29	20.0	465.0	20.7			
											20.0	460.0	20.4	20.6		
											20.0	465.0	20.7			
7379	16-11-2020	RMC	M20	SCPL		125	Footing		24-11-20	8	14.0	345.0	15.3			
											14.0	355.0	15.8	14.9		
											14.0	305.0	13.6			
7379	16-11-2020	RMC	M20	SCPL		125	Footing		15-12-20	29	20.0	495.0	22.0			
											20.0	495.0	22.0	22.1		
											20.0	505.0	22.4			
7380	16-11-2020	RMC	M20	SCPL		124	Footing		24-11-20	8	14.0	345.0	15.3			
											14.0	355.0	15.8	14.9		
											14.0	305.0	13.6			
7380	16-11-2020	RMC	M20	SCPL		124	Footing		15-12-20	29	20.0	455.0	20.2			
											20.0	465.0	20.7	20.1		
											20.0	440.0	19.6			
7381	16-11-2020	RMC	M20	SCPL		123	Footing		24-11-20	8	14.0	320.0	14.2			
											14.0	315.0	14.0	14.0		
											14.0	310.0	13.8			
7381	16-11-2020	RMC	M20	SCPL		123	Footing		15-12-20	29	20.0	460.0	20.4			
											20.0	475.0	21.1	20.7		
											20.0	460.0	20.4			
7382	20-11-2020	RMC	M25	RCPL		117	Col	1	28-11-20	8	17.5	395.0	17.6			
											17.5	395.0	17.6	17.8		
											17.5	410.0	18.2			
7382	20-11-2020	RMC	M25	RCPL		117	Col	1	19-12-20	29	25.0	595.0	26.4			
											25.0	595.0	26.4	26.7		
											25.0	610.0	27.1			
7383	24-11-2020	RMC	M25	RCPL		113	Col	1	2-12-20	8	17.5	405.0	18.0			
											17.5	415.0	18.4	17.9		
											17.5	390.0	17.3			
7383	24-11-2020	RMC	M25	RCPL		113	Col	1	23-12-20	29	25.0	590.0	26.2			
											25.0	580.0	25.8	26.6		
											25.0	625.0	27.8			
7384	25-11-2020	RMC	M25	RCPL		114	Col	1	2-12-20	7	17.5	390.0	17.3			
											17.5	405.0	18.0	17.9		
											17.5	415.0	18.4			
7384	25-11-2020	RMC	M25	RCPL		114	Col	1	23-12-20	28	25.0	590.0	26.2			
											25.0	605.0	26.9	26.8		
											25.0	615.0	27.3			

7385	26-11-2020	RMC	M25	RCPL		115	Col	1	2-12-20	6	17.5	395.0	17.6				
											17.5	410.0	18.2	18.1			
											17.5	420.0	18.7				
7385	26-11-2020	RMC	M25	RCPL		115	Col	1	23-12-20	27	25.0	605.0	26.9				
											25.0	605.0	26.9	26.8			
											25.0	600.0	26.7				
7386	08-12-2020	RMC	M20	SCPL		126	Slab	2	16-12-20	8	14.0	310.0	13.8				
											14.0	320.0	14.2	14.1			
											14.0	325.0	14.4				
7386	08-12-2020	RMC	M20	SCPL		126	Slab	2	6-1-21	29	20.0	495.0	22.0				
											20.0	490.0	21.8	21.7			
											20.0	480.0	21.3				
7387	08-12-2020	RMC	M20	SCPL		127	Slab	2	16-12-20	8	14.0	325.0	14.4				
											14.0	310.0	13.8	14.2			
											14.0	325.0	14.4				
7387	08-12-2020	RMC	M20	SCPL		127	Slab	2	6-1-21	29	20.0	500.0	22.2				
											20.0	510.0	22.7	22.5			
											20.0	510.0	22.7				
7388	08-12-2020	RMC	M20	SCPL		131	Slab	3	16-12-20	8	14.0	310.0	13.8				
											14.0	325.0	14.4	14.1			
											14.0	320.0	14.2				
7388	08-12-2020	RMC	M20	SCPL		131	Slab	3	6-1-21	29	20.0	510.0	22.7				
											20.0	510.0	22.7	22.8			
											20.0	520.0	23.1				
7389	09-12-2020	RMC	M25	RCPL		104	Col	2	16-12-20	7	17.5	395.0	17.6				
											17.5	410.0	18.2	18.1			
											17.5	420.0	18.7				
7389	09-12-2020	RMC	M25	RCPL		104	Col	2	6-1-21	28	25.0	595.0	26.4				
											25.0	610.0	27.1	26.7			
											25.0	600.0	26.7				
7390	10-12-2020	RMC	M25	RCPL		102	Col	2	18-12-20	8	17.5	400.0	17.8				
											17.5	415.0	18.4	18.1			
											17.5	405.0	18.0				
7391	13-12-2020	RMC	M20	RCPL		115	Slab	2	22-12-20	9	14.0	325.0	14.4				
											14.0	315.0	14.0	14.3			
											14.0	325.0	14.4				
7392	13-12-2020	RMC	M20	RCPL		116	Slab	2	22-12-20	9	14.0	335.0	14.9				
											14.0	315.0	14.0	14.4			
											14.0	320.0	14.2				