

QC - Concrete Cube Testing Report.															
Company:		MRMA(ULP)													
Project:		GMR													
Report for Month:		Oct to Dec - 2020													
Prepared By:		QC Team													
Date:		06-01-2021													
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
16053	19-09-2020	RMC	M20	SSVC		B(1,2,7 & 8)	Slab	4	27-9-20	8	14.0	335.0	14.9	14.2	
											14.0	315.0	14.0		
											14.0	310.0	13.8		
16053	19-09-2020	RMC	M20	SSVC		B(1,2,7 & 8)	Slab	4	17-10-20	28	20.0	510.0	22.7	22.6	
											20.0	510.0	22.7		
											20.0	505.0	22.4		
16054	22-09-2020	Site Mix	M25	SCPL		A(7 & 8)	COL	4	30-9-20	8	17.5	410.0	18.2	18.1	
											17.5	410.0	18.2		
											17.5	405.0	18.0		
16054	22-09-2020	Site Mix	M25	SCPL		A(7 & 8)	COL	4	20-10-20	28	25.0	560.0	24.9	24.7	
											25.0	545.0	24.2		
											25.0	560.0	24.9		
16055	24-09-2020	RMC	M25	Pointech		F(1)	COL	2	3-10-20	9	17.5	425.0	18.9		
											17.5	425.0	18.9	18.6	
											17.5	405.0	18.0		
16055	24-09-2020	RMC	M25	Pointech		F(1)	COL	2	24-10-20	30	25.0	575.0	25.6	25.9	
											25.0	585.0	26.0		
											25.0	590.0	26.2		
16056	24-09-2020	RMC	M25	Pointech		F(1)	COL	2	3-10-20	9	17.5	435.0	19.3		
											17.5	430.0	19.1	19.0	
											17.5	415.0	18.4		
16056	24-09-2020	RMC	M25	Pointech		F(1)	COL	2	24-10-20	30	25.0	595.0	26.4	26.4	
											25.0	590.0	26.2		
											25.0	595.0	26.4		
16057	29-09-2020	RMC	M20	SSVC		B(3,4,5,6)	Slab	6	8-10-20	9	14.0	345.0	15.3		
											14.0	325.0	14.4	14.6	
											14.0	315.0	14.0		
16057	29-09-2020	RMC	M20	SSVC		B(3,4,5,6)	Slab	6	27-10-20	28	20.0	510.0	22.7	22.6	
											20.0	505.0	22.4		
											20.0	510.0	22.7		
16058	20-10-2020	RMC	M20	SSVC		B(1,2,7,8)	Slab	6	28-10-20	8	14.0	355.0	15.8		
											14.0	335.0	14.9	15.2	
											14.0	335.0	14.9		
16058	20-10-2020	RMC	M20	SSVC		B(1,2,7,8)	Slab	6	18-11-20	29	20.0	515.0	22.9	22.8	
											20.0	515.0	22.9		
											20.0	510.0	22.7		

APPROVED
 09 JAN 2021
 PROJECT SUPERVISOR

