

QC - Concrete Cube Testing Report.															
Company:		MRM LLP													
Project:		AGH MLG													
Report for Month:	Jan - Feb - 20 - 21.														
Prepared By:	QC Team														
Date:		04--003-2021													
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
13731	02-12-2020	Site mix	M20	ashok		67	Slab	2	10-12-20	8	14.0	320.0	14.2		
											14.0	315.0	14.0	14.1	
											14.0	320.0	14.2		
13731	02-12-2020	Site mix	M20	ashok		67	Slab	2	30-12-20	28	20.0	460.0	20.4		
											20.0	440.0	19.6	19.9	
											20.0	445.0	19.8		
13732	08-12-2020	Site mix	M20	ashok		51	Slab	3	16-12-20	8	14.0	330.0	14.7		
											14.0	325.0	14.4	14.2	
											14.0	305.0	13.6		
13732	08-12-2020	Site mix	M20	ashok		51	Slab	3	6-1-21	29	20.0	465.0	20.7		
											20.0	455.0	20.2	20.5	
											20.0	465.0	20.7		
13733	08-12-2020	Site mix	M20	ashok		58	Slab	2	16-12-20	8	14.0	335.0	14.9		
											14.0	335.0	14.9	14.7	
											14.0	325.0	14.4		
13733	08-12-2020	Site mix	M20	ashok		58	Slab	2	6-1-21	29	20.0	475.0	21.1		
											20.0	455.0	20.2	20.7	
											20.0	470.0	20.9		
13734	09-12-2020	Site mix	M25	ashok		67	col	3	16-12-20	7	17.5	380.0	16.9		
											17.5	405.0	18.0	17.6	
											17.5	405.0	18.0		
13734	09-12-2020	Site mix	M25	ashok		67	col	3	6-1-21	28	25.0	580.0	25.8		
											25.0	585.0	26.0	25.7	
											25.0	570.0	25.3		
13735	15-12-2020	Site mix	M25	ashok		58	col	3	23-12-20	8	17.5	385.0	17.1		
											17.5	410.0	18.2	17.7	
											17.5	400.0	17.8		
13735	15-12-2020	Site mix	M25	ashok		58	col	3	13-1-21	29	25.0	550.0	24.4		
											25.0	580.0	25.8	25.6	
											25.0	595.0	26.4		
13736	19-12-2020	Site mix	M20	ashok		67	Slab	3	26-12-20	7	14.0	345.0	15.3		
											14.0	355.0	15.8	15.2	
											14.0	325.0	14.4		
13736	19-12-2020	Site mix	M20	ashok		67	Slab	3	16-1-21	28	20.0	450.0	20.0		
											20.0	455.0	20.2	20.1	
											20.0	450.0	20.0		
13737	19-12-2020	Site mix	M20	ashok		72	Slab	1	26-12-20	7	14.0	315.0	14.0		
											14.0	325.0	14.4	14.4	
											14.0	330.0	14.7		
13737	19-12-2020	Site mix	M20	ashok		72	Slab	1	16-1-21	28	20.0	465.0	20.7		
											20.0	465.0	20.7	20.9	
											20.0	480.0	21.3		
13738	20-12-2020	Site mix	M25	ashok		73	col	2	29-12-20	9	17.5	395.0	17.6		
											17.5	405.0	18.0	17.9	
											17.5	405.0	18.0		
13738	20-12-2020	Site mix	M25	ashok		73	col	2	18-1-21	29	25.0	570.0	25.3		
											25.0	580.0	25.8	25.8	
											25.0	590.0	26.2		
13739	23-12-2020	Site mix	M25	ashok		72	col	2	31-12-20	8	17.5	390.0	17.3		
											17.5	400.0	17.8	17.8	
											17.5	410.0	18.2		
13739	23-12-2020	Site mix	M25	ashok		72	col	2	21-1-21	29	25.0	575.0	25.6		
											25.0	585.0	26.0	25.9	
											25.0	585.0	26.0		
13740	10-01-2021	Site mix	M20	ashok		73	Slab	2	16-1-21	6	14.0	310.0	13.8		
											14.0	325.0	14.4	14.2	
											14.0	325.0	14.4		

[illegible]