

QC - Concrete Cube Testing Report.															
Company:		SOVLLP													
Project:		SOV													
Report for Month:		Jan - Feb -20 - 21.													
Prepared By:		QC Team													
Date:		07-03-2021													
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
7411	09-01-2021	RMC	M20	RCPL		108	footing		6-2-21	28	20.0	455.0	20.2		
											20.0	465.0	20.7	20.4	
											20.0	460.0	20.4		
7412	12-01-2021	RMC	M25	SCPL		125	Col	1	10-2-21	29	25.0	560.0	24.9		
											25.0	585.0	26.0	25.6	
											25.0	580.0	25.8		
7413	12-01-2021	RMC	M20	SCPL		124	P.B.		10-2-21	29	20.0	455.0	20.2		
											20.0	445.0	19.8	20.2	
											20.0	465.0	20.7		
7414	18-01-2021	RMC	M25	SCPL		132	Col	1	16-2-21	29	25.0	570.0	25.3		
											25.0	595.0	26.4	25.9	
											25.0	585.0	26.0		
7415	18-01-2021	RMC	M20	SCPL		123	P.B.		16-2-21	29	20.0	465.0	20.7		
											20.0	460.0	20.4	20.5	
											20.0	460.0	20.4		
7416	20-01-2021	RMC	M20	RCPL		111	P.B.		18-2-21	29	20.0	475.0	21.1		
											20.0	475.0	21.1	20.7	
											20.0	450.0	20.0		
7417	21-01-2021	RMC	M20	SCPL		133	P.B.		18-2-21	28	20.0	470.0	20.9		
											20.0	470.0	20.9	20.8	
											20.0	465.0	20.7		
7418	22-01-2021	RMC	M25	RCPL		115	Col	1	18-2-21	27	25.0	590.0	26.2		
											25.0	590.0	26.2	25.9	
											25.0	570.0	25.3		
7419	24-01-2021	RMC	M20	RCPL		121	footing		20-2-21	27	20.0	450.0	20.0		
											20.0	465.0	20.7	20.3	
											20.0	455.0	20.2		
7420	25-01-2021	RMC	M25	SCPL		124	Col	1	23-2-21	29	25.0	590.0	26.2		
											25.0	595.0	26.4	26.2	
											25.0	585.0	26.0		
7421	25-01-2021	RMC	M20	SCPL		134	P.B.		1-2-21	7	14.0	360.0	16.0		
											14.0	340.0	15.1	14.9	
											14.0	305.0	13.6		
7421	25-01-2021	RMC	M20	SCPL		134	P.B.		20-2-21	26	20.0	460.0	20		