

QC - Concrete Cube Testing Report:															
Company:		GVRC													
Project:		Innopolis													
Report for Month:		Feb - Mar -2021													
Prepared By:		QC Team													
Date:		06-04-2021													
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
14176	15-02-2021	RMC	M25	Ishaq		2727	Slab	5	15-3-21	28	25.0	585.0	26.0		
											25.0	585.0	26.0	25.9	
											25.0	580.0	25.8		
14177	17-02-2021	RMC	M25	Pointeck		4545	P.B.		17-3-21	28	25.0	580.0	25.8		
											25.0	585.0	26.0	26.1	
											25.0	595.0	26.4		
14178	24-02-2021	RMC	M25	Pointeck		4545	P.B.		24-3-21	28	25.0	555.0	24.7		
											25.0	585.0	26.0	25.5	
											25.0	580.0	25.8		
14179	25-02-2021	RMC	M30	Ishaq		2727	COL	5	24-3-21	27	30.0	695.0	30.9		
											30.0	690.0	30.7	30.7	
											30.0	690.0	30.7		
14180	27-02-2021	RMC	M25	Pointeck		4545	P.B.		6-3-21	7	17.5	385.0	17.1		
											17.5	385.0	17.1	17.6	
											17.5	415.0	18.4		
14180	27-02-2021	RMC	M25	Pointeck		4545	P.B.		27-3-21	28	25.0	585.0	26.0		
											25.0	585.0	26.0	26.3	
											25.0	605.0	26.9		
14181	01-03-2021	RMC	M25	Pointeck		4545	P.B.		10-3-21	9	17.5	395.0	17.6		
											17.5	395.0	17.6	17.8	
											17.5	410.0	18.2		
14181	01-03-2021	RMC	M25	Pointeck		4545	P.B.		30-3-21	29	25.0	580.0	25.8		
											25.0	580.0	25.8	26.1	
											25.0	600.0	26.7		
14182	03-03-2021	RMC	M25	Pointeck		4545	P.B.		10-3-21	7	17.5	405.0	18.0		
											17.5	410.0	18.2	17.9	
											17.5	390.0	17.3		
14182	03-03-2021	RMC	M25	Pointeck		4545	P.B.		1-4-21	29	25.0	575.0	25.6		
											25.0	580.0	25.8	25.9	
											25.0	595.0	26.4		
14183	04-03-2021	RMC	M25	Pointeck		4545	P.B.		10-3-21	6	17.5	410.0	18.2		
											17.5	415.0	18.4	18.1	
											17.5	395.0	17.6		
14183	04-03-2021	RMC	M25	Pointeck		4545	P.B.		1-4-21	28	25.0	595.0	26.4		
											25.0	595.0	26.4	26.4	
											25.0	590.0	26.2		
14184	06-03-2021	RMC	M25	Pointeck		4545	P.B.		13-3-21	7	17.5	395.0	17.6		
											17.5	390.0	17.3	17.4	
											17.5	390.0	17.3		
14184	06-03-2021	RMC	M25	Pointeck		4545	P.B.		3-4-21	28	25.0	550.0	24.4		
											25.0	595.0	26.4	25.6	
											25.0	586.0	26.0		
14185	16-03-2021	RMC	M25	Pointeck		5600c	COL	1	24-3-21	8	17.5	405.0	18.0		
											17.5	385.0	17.1	17.7	
											17.5	405.0	18.0		