

QC - Concrete Cube Testing Report.															
Company:		SOVLLP													
Project:		SOV													
Report for Month:		Feb - Mar -20 - 21.													
Prepared By:		QC Team													
Date:		06-04-2021													
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
7444	04-03-2021	RMC	M20	RCPL		113	slab	1	13-3-21	9	14.0	315.0	14.0		
											14.0	325.0	14.4		
											14.0	310.0	13.8		
7444	04-03-2021	RMC	M20	RCPL		113	slab	1	31-3-21	27	20.0	445.0	19.8	20.1	
											20.0	460.0	20.4		
											20.0	450.0	20.0		
7445	04-03-2021	RMC	M20	RCPL		115	slab	2	13-3-21	9	14.0	320.0	14.2	14.3	
											14.0	330.0	14.7		
											14.0	315.0	14.0		
7445	04-03-2021	RMC	M20	RCPL		115	slab	2	31-3-21	27	20.0	450.0	20.0	20.3	
											20.0	465.0	20.7		
											20.0	455.0	20.2		
7446	05-03-2021	RMC	M20	SCPL		125	slab	1	13-3-21	8	14.0	325.0	14.4	14.5	
											14.0	335.0	14.9		
											14.0	320.0	14.2		
7446	05-03-2021	RMC	M20	SCPL		125	slab	1	2-4-21	28	20.0	455.0	20.2	20.5	
											20.0	470.0	20.9		
											20.0	460.0	20.4		
7447	05-03-2021	Site Mix	M25	RCPL		101	col	3	13-3-21	8	17.5	385.0	17.1	17.7	
											17.5	395.0	17.6		
											17.5	415.0	18.4		
7447	05-03-2021	Site Mix	M25	RCPL		101	col	3	2-4-21	28	25.0	565.0	25.1	25.4	
											25.0	570.0	25.3		
											25.0	580.0	25.8		
7448	05-03-2021	Site Mix	M25	RCPL		102	col	3	13-3-21	8	17.5	390.0	17.3	17.6	
											17.5	400.0	17.8		
											17.5	400.0	17.8		
7448	05-03-2021	Site Mix	M25	RCPL		102	col	3	2-4-21	28	25.0	570.0	25.3	25.6	
											25.0	575.0	25.6		
											25.0	585.0	26.0		
7449	06-03-2021	RMC	M20	RCPL		116	slab	2	13-3-21	7	14.0	320.0	14.2	14.3	
											14.0	330.0	14.7		
											14.0	315.0	14.0		
7449	06-03-2021	RMC	M20	RCPL		116	slab	2	2-4-21	27	20.0	440.0	19.6	20.1	
											20.0	450.0	20.0		
											20.0	465.0	20.7		
7450	10-03-2021	RMC	M20	RCPL		110	plinth		18-3-21	8	14.0	325.0	14.4	14.5	
											14.0	335.0	14.9		
											14.0	320.0	14.2		
7451	10-03-2021	RMC	M25	SCPL		125	col	2	18-3-21	8	17.5	395.0	17.6	17.9	
											17.5	405.0	18.0		
											17.5	405.0	18.0		

7452	11-03-2021	RMC	M20	RCPL	106	plinth	18-3-21	7	14.0	330.0	14.7			
									14.0	340.0	15.1	14.7		
									14.0	325.0	14.4			
7453	15-03-2021	Site Mix	M25	RCPL	104	col	3	23-3-21	8	17.5	395.0	17.6		
										17.5	405.0	18.0	17.9	
										17.5	405.0	18.0		
7454	15-03-2021	RMC	M20	SCPL	138	footing	23-3-21	8	14.0	335.0	14.9			
									14.0	345.0	15.3	14.9		
									14.0	325.0	14.4			
7455	15-03-2021	RMC	M20	SCPL	139	footing	23-3-21	8	14.0	340.0	15.1			
									14.0	350.0	15.6	15.1		
									14.0	330.0	14.7			
7456	18-03-2021	RMC	M20	RCPL	107	plinth	27-3-21	9	14.0	335.0	14.9			
									14.0	345.0	15.3	15.0		
									14.0	335.0	14.9			
7457	18-03-2021	RMC	M20	Ishaq	162	footing	27-3-21	9	14.0	345.0	15.3			
									14.0	355.0	15.8	15.3		
									14.0	335.0	14.9			
7458	18-03-2021	RMC	M20	Ishaq	183	footing	27-3-21	9	14.0	350.0	15.6			
									14.0	360.0	16.0	15.6		
									14.0	340.0	15.1			
7459	23-03-2021	RMC	M20	SCPL	124	slab	1	30-3-21	7	14.0	355.0	15.8		
										14.0	365.0	16.2	15.8	
										14.0	345.0	15.3		