

QC - Concrete Cube Testing Report.																
Company:			MRMA(LLP)													
Project:			GMR													
Report for Month:			Feb to March -20 21													
Prepared By:			QC Team													
Date:			10-04-2021													
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks	
16082	02-02-2021	RMC	M20	Pointech		F-block	ab(301&302)	4	10-2-21	8	14.0	320.0	14.2			
											14.0	325.0	14.4	14.1		
											14.0	310.0	13.8			
16082	02-02-2021	RMC	M20	Pointech		F-block	ab(301&302)	4	1-3-21	27	20.0	465.0	20.7			
											20.0	445.0	19.8	20.2		
											20.0	455.0	20.2			
16083	08-02-2021	RMC	M20	Pointech		F-block	ab(202&203)	3	16-2-21	8	14.0	325.0	14.4			
											14.0	330.0	14.7	14.4		
											14.0	315.0	14.0			
16083	08-02-2021	RMC	M20	Pointech		F-block	ab(202&203)	3	8-3-21	28	20.0	470.0	20.9			
											20.0	450.0	20.0	20.4		
											20.0	455.0	20.2			
16084	10-02-2021	RMC	M20	SSVC		G-block	ootings(1,5)		16-2-21	6	14.0	310.0	13.8			
											14.0	320.0	14.2	14.1		
											14.0	325.0	14.4			
16084	10-02-2021	RMC	M20	SSVC		G-block	ootings(1,5)		8-3-21	26	20.0	460.0	20.4			
											20.0	440.0	19.6	20.1		
											20.0	455.0	20.2			
16085	11-02-2021	RMC	M20	Bikshapathi		C-block	ootings(4,5)		19-2-21	8	14.0	320.0	14.2			
											14.0	325.0	14.4	14.3		
											14.0	320.0	14.2			
16085	11-02-2021	RMC	M20	Bikshapathi		C-block	ootings(4,5)		11-3-21	28	20.0	465.0	20.7			
											20.0	445.0	19.8	20.2		
											20.0	455.0	20.2			
16086	12-02-2021	Site Mix	M25	Pointech		F-block	OL(202-203)	4	19-2-21	7	17.5	410.0	18.2			
											17.5	395.0	17.6	17.7		
											17.5	390.0	17.3			
16086	12-02-2021	Site Mix	M25	Pointech		F-block	OL(202-203)	4	11-3-21	27	25.0	580.0	25.8			
											25.0	580.0	25.8	25.6		
											25.0	570.0	25.3			
16087	06-03-2021	RMC	M20	Pointech		F-block	ab(401&402)	5	15-3-21	9	14.0	330.0	14.7			
											14.0	335.0	14.9	14.7		
											14.0	325.0	14.4			
16087	06-03-2021	RMC	M20	Pointech		F-block	ab(401&402)	5	5-4-21	30	20.0	470.0	20.9			
											20.0	455.0	20.2	20.4		
											20.0	450.0	20.0			
16088	08-03-2021	RMC	M20	Bikshapathi		C-block	Raft footing		15-3-21	7	14.0	335.0	14.9			
											14.0	345.0	15.3	15.1		
											14.0	340.0	15.1			
16089	14-03-2021	RMC	M20	Bikshapathi		C-block	Slab(4&5)	1	22-3-21	8	14.0	330.0	14.7			
											14.0	340.0	15.1	14.8		
											14.0	330.0	14.7			
16090	15-03-2021	Site Mix	M25	Pointech		F-block	OL(501&502)	6	22-3-21	7	17.5	415.0	18.4			
											17.5	395.0	17.6	17.9		
											17.5	395.0	17.6			
16091	17-03-2021	RMC	M20	Bikshapathi		C-block	Raft footing		25-3-21	8	14.0	340.0	15.1			
											14.0	340.0	15.1	15.2		
											14.0	345.0	15.3			