

S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
16088	08-03-2021	RMC	M20	Bikshapathi		C-block	Kaft footing		6-4-21	29	20.0	445.0	19.8		
											20.0	455.0	20.2	20.2	
											20.0	465.0	20.7		
16089	14-03-2021	RMC	M20	Bikshapathi		C-block	Slab(4&5)	1	12-4-21	29	20.0	455.0	20.2		
											20.0	465.0	20.7	20.6	
											20.0	470.0	20.9		
16090	15-03-2021	Site Mix	M25	Poitech		F-block	L(501&502)	6	12-4-21	28	25.0	575.0	25.6		
											25.0	585.0	26.0	25.5	
											25.0	560.0	24.9		
16091	17-03-2021	RMC	M20	Bikshapathi		C-block	Kaft footing		15-4-21	29	20.0	460.0	20.4		
											20.0	470.0	20.9	20.8	
											20.0	475.0	21.1		
16092	23-03-2021	RMC	M20	Poitech		F-block	b(202&203)	3	31-3-21	8	14.0	315.0	14.0		
											14.0	310.0	13.8	14.1	
											14.0	325.0	14.4		
16092	23-03-2021	RMC	M20	Poitech		F-block	b(202&203)	3	21-4-21	29	20.0	465.0	20.7		
											20.0	475.0	21.1	20.8	
											20.0	465.0	20.7		
16093	30-03-2021	RMC	M20	SSVC		G-block	oting(3&4)		8-4-21	9	14.0	325.0	14.4		
											14.0	315.0	14.0	14.4	
											14.0	335.0	14.9		
16093	30-03-2021	RMC	M20	SSVC		G-block	oting(3&4)		28-4-21	29	20.0	460.0	20.4		
											20.0	465.0	20.7	20.4	
											20.0	450.0	20.0		
16094	04-04-2021	Site Mix	M25	Bikshapathi		C-block	Sump walls		12-4-21	8	17.5	395.0	17.6		
											17.5	395.0	17.6	17.8	
											17.5	410.0	18.2		
16095	05-04-2021	Site Mix	M25	Bikshapathi		C-block	Sump walls		12-4-21	7	17.5	415.0	18.4		
											17.5	395.0	17.6	17.9	
											17.5	395.0	17.6		
16096	24-04-2021	Site Mix	M25	SSVC		B-block	L(601&602)	8	3-5-21	9	17.5	400.0	17.8		
											17.5	390.0	17.3	17.6	
											17.5	400.0	17.8		
16097	25-04-2021	Site Mix	M25	SSVC		B-block	L(603&604)	8	3-5-21	8	17.5	410.0	18.2		
											17.5	410.0	18.2	17.9	
											17.5	390.0	17.3		