

GOVERNMENT OF TELANGANA STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT NO OBJECTION CERTIFICATE



PRINT WHE					AND AND ASSESSMENT	
Ack. No.:	145930002018			同类杂类类面		
NOC:	0005340/PROV/Medchal/2018					
NOC TYPE:	PROVISIONAL*					
Applicant Details:	SRI SUDHIR U MEHTA,8978144447,SY.NO 19, MALLAPUR VILLAGE, GHMC KAPRA CIRCLE, UPPAL MANDAL, MEDCHAL DIST.					
Building for which NOC issued:	GULMOHAR RESIDENCY AND JADE ESTATES AMENITITES BLOCK, SY.NO 19, MALLAPUR VILLAGE, GHMC KAPRA CIRCLE, UPPAL MANDAL, MEDCHAL DIST./-Kapra/Medchal					
Concessions in Setback	s Given in Lieu o	f Land Surrendere	d in Road	No		
Widening:				INO		
Plot Area (Sq. Mtrs):	22756.00	Height (Metres)	: 20.90			
Open Spaces (Metres):	North: (F) 7.00	South: 7.00	East: 7.00	West: 7.00		
No. of Floors: 2 Cellars, 0 Stilts, 1 Ground, 6 Floors, 0 Terrace			Occupancy Type:	intended for use division D-3, bu for less than 300	ASSEMBLY D-4 any building primarily intended for use as described in subdivision D-3, but with accommodation for less than 300 persons with no permanent seating arrangements.	
Total Built-up Area (Sq.Mtrs):	3815.36			No. of Staircase Required/Propo	es 2 sed: th	
Fees Paid (Rs):	38154		Staircases:	Aggregate Widt Required/Propo (Metres):		
3.5		. I		T 11 5 D / W/	ends and	
Minimum	Fire Fighting Inst		Provided as p	er Table 7, Part-IV o	of NBC, 2016:	
Fire Extinguisher:	38	First Aid Hose Reel:	9	Wet Riser:	1	
Down Comer:	0	Yard Hydrant:	7	Automatic Sprinkler System:	530	
Manually Operated Electronic Fire Alarm Systemss:	9	Terrace Tank (Litres):	10000			
Automatic Detection and Alarm System:	48	Underground Static Water Storage Tank (Litres):	150000			
Pump Near						
Underground Static Water Storage Tank	Type	Quantity		acity in Litres/min)		
(Fire Pump) with	Electrical	1	2280 2280			
Minimum Pressure of	Diesel	1				
3.5 kg/cm2 at Terrace Level	Jockey	1	180			
Fire Pump at the						
Terrace Tank Level with Minimum	(Capacity in Lit 900	tres/min)				
Pressure of 2.0 kg/cm ²	1111 24	17	1 1	11 1 11 '!! ^	1	

It is informed that, the builder along with architect and site engineer shall be held responsible for any deviations from the Provisional No Objection Certificate issued and necessary Legal Action will be initiated as per provisions of Fire Service Act.

The Provisional No Objection Certificate is issued with an advice that the Multi storeyed building should not be occupied and the operations shall not be commenced without obtaining No Objection Certificate for Occupancy from this Department about the satisfactory installation of above fire safety measures.

"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE" For details and conditions of Provisional No Objection Certificate, refer overleaf.



GOVERNMENT OF TELANGANA STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT NO OBJECTION CERTIFICATE



The Provisional No Objection Certificate is issued subject to following conditions:

- a. The applicant should follow the Serial No. 1, 4, 8, 9 of Form No.18 [See Rule 15(1) (f)] of Telangana Fire and Emergency Operations and Levy of Fee Rules, 2006.
- b. In pursuance of the orders of the Hon'ble High Court mentioned above at Sl.No. 1 of Form No.18 and on the basis of the recommendations of the building inspection committee, this Provisional No Objection Certificate is issued.
- c. All the fire safety systems shall be provided as per the provisions of Part-4 of N.B.C of India 2016 as amended from time to time.
- d. 'For buildings 15 Metres and above in height, Additional Requirements as per Annex E, Part-IV of National Building Code of India, 2016 shall be followed
- e. The applicant should follow the Amendment 16of G.O.MS.No. 7 MA&UD (M1) Dept. Dated: 05-01-2016 wherein ...2 mts wide green planting strip (where the setback is 9m and above), which shall be soft green planting, to facilitate movement of fire fighting vehicles and effective fire fighting operation"
- f. The applicant should follow Clause 3.4.10, Clause 4.5 and 4.6, Clause 3.4.5, Clause 3.4.5.6, Clause 3.4.5.4, Clause 3.4.6.1, Clause 3.4.6.2, Clause 3.4.6.3, Clause 3.4.6.4, Clause 3.4.7, Clause 3.4.8, Clause 3.4.11, Clause 3.4.11, Clause 3.4.6.5, Clause 4.2, Clause 4.3, Clause 4.4.2, Clause 4.4.2.5, Clause 4.7, Clause 4.8, Clause 4.9, Clause 4.11, Clause 5.1, Clause 5.1.3, Clause 5.1.4, Clause 5.1.5, Clause 5.1.6, Clause 5.1.8, Clause 5.1.9, Clause 5.3, Clause 6. Additional Occupancy Wise Requirements, Annexure F, G, H of Clause 6, of Part-4 of N.B.C of India 2016
- g. A Qualified Fire Officer with experience not less than 3 years shall be appointed for large educational complexes, buildings with height 30. M and above, Residential Buildings with height 60 m and above, Institutional buildings with height 15 m and above, Starred Hotels and D-6 Occupancy
- h. The floor wise built-up areas of the building are as follows:

FloorType	BuildUpArea
Cellar-1	704.00
Cellar	704.00
Ground	400.50
1st Floor	400.50
2nd Floor	400.50
3rd Floor	400.50
4th Floor	400.50
5th Floor	234.34
6th Floor	170.52
Total	3815.36