

From

23rd March 2021

MDN Prasad and two other petitioners
Villa 66, Bloomdale,
Shamirpet – 500101
Medchal District

To

1. The Secretary,
HMDA,
Hyderabad
2. The Planning Officer (Medchal Zone)
HMDA
Hyderabad – 500038

SEWAGE CONNECTIONS IN SY NO.1139, SHAMIRPET VILLAGE
BY KADAKIA AND MODI HOUSING

Dear Sirs,

Please refer the directions of Secretary, HMDA on 06th March 2021, in the hearing consequent to the Hon'ble High Court of Telangana order dated 14th October 2020.

2. It is understood from the site engineer of the developer Kadakia and Modi Housing, that in order to meet the deadline set by the Secretary, HMDA is undertaking sewage connection work, inadequate [32 mm (1 ¼ inches) CPVC line] and improper sewage lines are laid to connect to the Gram Panchayat main sewage. The length of this line is about 150 metres without any inspection pits. Generally, CPVC pipes are laid for pumping water and not for raw sewage. Moreover, such narrow pipeline with a 1 HP submersible pump is highly prone for frequent blockages due to solid in the raw sewage. Photograph (Appendix) of the pipe being laid is placed for information.

3. It is requested that the developer be advised to undertake quality work by laying sewage lines of adequate diameter with standard inspection pits for long-term trouble-free operations.

Warm Regards


(MDN Prasad)
Petitioner


(B Raja Rao)
Petitioner


(R Rajasekhhar)
Petitioner

Encl: **As stated in Para 2**

Copy: Kadakia and Modi Housing

PHOTOGRAPH SHOWING THE DIAMETER OF THE SEWAGE PIPE BEING LAID
TO CONNECT SEWAGE PITS



W. [Signature]