

Borewell details & location of GV Discovery center pvt.ltd site

Company:	GV Discovery center pvt.ltd	Date:	20-07-2021		
Site:	Genopolis	Prepared by:	R.Vineetha reddy		
Report date	20-07-2021	Approved by:	K.Narsing rao		
List of Bore well points in GV Discovery center pvt.ltd					
Sl.no	Depth of bore well	Depth of pump	Capacity of pump	Location	Status
1	590 feet	560 feet fixed	5 HP / 3- phase	Near 191 block(south east)	Using.
2	900 feet	New bore point	3 HP / 3 phase	Near container side	New bore point
3	900 feet	New bore point	3 HP/ 3 phase	Near south security kiosk	New bore point
4	460 feet	410 feet fixed	3 HP / 3 phase	Near tower	Using.



Machinery details and location of GV Discovery center pvt ltd site

Company:	GV Discovery center pvt ltd	Date:	20.07.2021		
Site:	Genopolis	Prepared by:	R.Vineetha reddy		
Report date	20-07-2021	Approved by:	K.Narsing rao		
List of Machinery details of GV Discovery center pvt. ltd					
Slno	Name of equipment	Type	Capacity of pump	Location	Status
1	Generator	Diesel	25 Kb	Near transformer	working
2	Earth compacting machine	Diesel	1.5 Ton	-	working



Details Of Electricity Meter , Sub Meter and Locations

Company:	GV Discovery center pvt ltd	Date:	20-07-2021
Site:	Genopolis	Prepared by:	R.Vineetha reddy
Report date	20-07-2021	Approved by:	K.Narsing rao

List of main meters & sub meters in GV Discovery center pvt ltd

Sl.no	Meter nos	Meter Location	Using for	Remarks
1	0308-02727	Fixed at south side near transformer	Entire construction Site	Main meter
2	115774	Fixed at tower0	Used for surasani infra	Sub meter
3	115756	Fixed at tower	Used for homeline infra	Sub meter
4	115749	Fixed at tower	Used for lights &bore	Sub meter


APPROVED BY
20 JUL 2021
K. NARSINGA RAO
Project Manager

Details Of Dewatering pumps and Locations

Company:	Gv discovery center pvt.lts	Date:	20-07-2021
Site:	Genopolis	Prepared by:	R.Vineetha reddy
Report date	20-07-2021	Approved by:	K.Narsing rao

List of Pumps and Motors in GV Discovery center pvt ltd site

S.No	Capacity	Type of motors	Using for	Remarks
1	3 HP	Self priming dewatering pump	-	Working.
2	3 HP	Submersible pump	curing	At lift pit no 1
3	3 HP	Submersible pump	curing	At lift pit no 1
4	2 HP	Submersible pump	curing	At lift pit no 3
5	3 HP	Submersible pump	Curing	Working.
6	1 HP	MS Frames for self priming pump	At sump for Dewatering	Working.

