

QC - Concrete Cube Testing Report.															
Company:		GVDC													
Project:		Genopolis													
Report for Month:		June - Aug (20 - 21).													
Prepared By:		QC Team													
Date:		02-09-2021													
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
20132	29-06-2021	RMC	M25	Kurunakar		chemical	COL	1	7-7-21	8	17.5	395.0	17.6		
											17.5	395.0	17.6	17.4	
											17.5	385.0	17.1		
20132	29-06-2021	RMC	M25	Kurunakar		chemical	COL	1	27-7-21	28	25.0	595.0	26.4		
											25.0	585.0	26.0	25.8	
											25.0	560.0	24.9		
20133	10-07-2021	RMC	M35	Anand		119	Slab	2	19-7-21	9	23.5	560.0	24.9		
											23.5	530.0	23.6	23.9	
											23.5	525.0	23.3		
20133	10-07-2021	RMC	M35	Anand		119	Slab	2	7-8-21	28	35.0	790.0	35.1		
											35.0	785.0	34.9	35.1	
											35.0	795.0	35.3		
20134	26-07-2021	RMC	M35	Anand		119	COL	3	3-8-21	8	23.5	565.0	25.1		
											23.5	535.0	23.8	24.2	
											23.5	535.0	23.8		
20134	26-07-2021	RMC	M35	Anand		119	COL	3	23-8-21	28	35.0	795.0	35.3		
											35.0	790.0	35.1	35.2	
											35.0	790.0	35.1		
20135	03-08-2021	RMC	M35	Kurunakar		191	Slab	1	11-8-21	8	23.5	555.0	24.7		
											23.5	525.0	23.3	23.6	
											23.5	515.0	22.9		
20135	03-08-2021	RMC	M35	Kurunakar		191	Slab	1	31-8-21	28	35.0	800.0	35.6		
											35.0	795.0	35.3	35.4	
											35.0	795.0	35.3		
20136	09-08-2021	RMC	M35	Anand		119	tie beams	3	17-8-21	8	23.5	565.0	25.1		
											23.5	535.0	23.8	24.1	
											23.5	525.0	23.3		
20137	12-08-2021	RMC	M35	Anand		119	tie beams	3	20-8-21	8	23.5	560.0	24.9		
											23.5	530.0	23.6	23.9	
											23.5	520.0	23.1		
20138	14-08-2021	RMC	M35	Kurunakar		191	COL	2	23-8-21	9	23.5	555.0	24.7		
											23.5	520.0	23.1	23.5	
											23.5	510.0	22.7		

[illegible]