

QC - Concrete Cube Testing Report.																
Company:		SOVLLP														
Project:		SOV														
Report for Month:		July - Aug = 2021.														
Prepared By:		QC Team														
Date:		01-08-2021														
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bangalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks	
7499	11-06-2021	RMC	M20	Ishaq		160	footing		19-6-21	8	14.0	325.0	14.4			
											14.0	325.0	14.4	14.4		
											14.0	320.0	14.2			
7499	11-06-2021	RMC	M20	Ishaq		160	footing		9-7-21	28	20.0	465.0	20.7			
											20.0	455.0	20.2	20.3		
											20.0	450.0	20.0			
7500	11-06-2021	RMC	M20	Ishaq		185	footing		19-6-21	8	14.0	330.0	14.7			
											14.0	330.0	14.7	14.6		
											14.0	325.0	14.4			
7500	11-06-2021	RMC	M20	Ishaq		185	footing		9-7-21	28	20.0	470.0	20.9			
											20.0	460.0	20.4	20.5		
											20.0	455.0	20.2			
7501	12-06-2021	RMC	M20	SCPL		142	plinth		19-6-21	7	14.0	325.0	14.4			
											14.0	320.0	14.2	14.3		
											14.0	320.0	14.2			
7501	12-06-2021	RMC	M20	SCPL		142	plinth		9-7-21	27	20.0	465.0	20.7			
											20.0	450.0	20.0	20.1		
											20.0	445.0	19.8			
7502	15-06-2021	RMC	M25	RCPL		117	Col	1	23-6-21	8	17.5	395.0	17.6			
											17.5	390.0	17.3	17.7		
											17.5	410.0	18.2			
7502	15-06-2021	RMC	M25	RCPL		117	Col	1	13-7-21	28	25.0	585.0	26.0			
											25.0	585.0	26.0	26.1		
											25.0	595.0	26.4			
7503	18-06-2021	RMC	M20	RCPL		112	slab	1	26-6-21	8	14.0	325.0	14.4			
											14.0	325.0	14.4	14.3		
											14.0	315.0	14.0			
7503	18-06-2021	RMC	M20	RCPL		112	slab	1	16-7-21	28	20.0	470.0	20.9			
											20.0	455.0	20.2	20.4		
											20.0	455.0	20.2			
7504	21-06-2021	RMC	M25	RCPL		120	Col	1	29-6-21	8	17.5	390.0	17.3			
											17.5	385.0	17.1	17.5		
											17.5	405.0	18.0			
7504	21-06-2021	RMC	M25	RCPL		120	Col	1	19-7-21	28	25.0	590.0	26.2			
											25.0	585.0	26.0	26.4		
											25.0	605.0	26.9			
7505	22-06-2021	RMC	M20	SCPL		141	plinth		29-6-21	7	14.0	345.0	15.3			
											14.0	335.0	14.9	14.9		
											14.0	325.0	14.4			
7505	22-06-2021	RMC	M20	SCPL		141	plinth		19-7-21	27	20.0	455.0	20.2			
											20.0	465.0	20.7	20.7		
											20.0	480.0	21.3			
7506	22-06-2021	RMC	M25	RCPL		119	Col	1	29-6-21	7	17.5	395.0	17.6			
											17.5	390.0	17.3	17.6		
											17.5	405.0	18.0			
7506	22-06-2021	RMC	M25	RCPL		119	Col	1	19-7-21	27	25.0	575.0	25.6			
											25.0	585.0	26.0	25.9		
											25.0	590.0	26.2			

7507	26-06-2021	RMC	M20	Ishaq		183	plinth		3-7-21	7	14.0	340.0	15.1			
											14.0	330.0	14.7	14.7		
											14.0	320.0	14.2			
7507	26-06-2021	RMC	M20	Ishaq		183	plinth		24-7-21	28	20.0	450.0	20.0			
											20.0	460.0	20.4	20.5		
											20.0	475.0	21.1			
7508	26-06-2021	RMC	M20	Ishaq		162	plinth		3-7-21	7	14.0	350.0	15.6			
											14.0	340.0	15.1	15.1		
											14.0	330.0	14.7			
7508	26-06-2021	RMC	M20	Ishaq		162	plinth		24-7-21	28	20.0	460.0	20.4			
											20.0	470.0	20.9	20.8		
											20.0	475.0	21.1			
7509	29-06-2021	RMC	M25	SCPL		140	Col	1	7-7-21	8	17.5	405.0	18.0			
											17.5	400.0	17.8	18.1		
											17.5	415.0	18.4			
7509	29-06-2021	RMC	M25	SCPL		140	Col	1	27-7-21	28	25.0	590.0	26.2			
											25.0	590.0	26.2	26.1		
											25.0	585.0	26.0			
7510	30-06-2021	RMC	M20	SCPL		133	slab	1	27-7-21	27	20.0	465.0	20.7			
											20.0	475.0	21.1	20.9		
											20.0	470.0	20.9			
7511	30-06-2021	RMC	M20	SCPL		134	slab	1	27-7-21	27	20.0	470.0	20.9			
											20.0	480.0	21.3	21.1		
											20.0	475.0	21.1			
7512	30-06-2021	RMC	M20	SCPL		135	slab	1	27-7-21	27	20.0	475.0	21.1			
											20.0	480.0	21.3	21.2		
											20.0	475.0	21.1			
7513	30-06-2021	RMC	M20	SCPL		122	slab	1	27-7-21	27	20.0	460.0	20.4			
											20.0	470.0	20.9	20.7		
											20.0	465.0	20.7			
7514	30-06-2021	RMC	M25	SCPL		142	Col	1	27-7-21	27	25.0	580.0	25.8			
											25.0	575.0	25.6	25.9		
											25.0	595.0	26.4			
7515	01-07-2021	RMC	M25	SCPL		141	Col	1	27-7-21	26	25.0	585.0	26.0			
											25.0	580.0	25.8	26.1		
											25.0	600.0	26.7			
7516	01-07-2021	RMC	M25	RCPL		112	Col	2	27-7-21	26	25.0	590.0	26.2			
											25.0	585.0	26.0	26.4		
											25.0	605.0	26.9			
7517	01-07-2021	RMC	M20	Shravan		148	footing		27-7-21	26	20.0	465.0	20.7			
											20.0	475.0	21.1	20.9		
											20.0	470.0	20.9			

7518	01-07-2021	RMC	M20	Ishaq		163	plinth		27-7-21	26	20.0	470.0	20.9			
											20.0	480.0	21.3	21.1		
											20.0	475.0	21.1			
7519	01-07-2021	RMC	M20	Ishaq		182	plinth		27-7-21	26	20.0	460.0	20.4			
											20.0	470.0	20.9	20.7		
											20.0	465.0	20.7			
7520	03-07-2021	RMC	M20	RCPL		107	slab	1	30-7-21	27	20.0	460.0	20.4			
											20.0	475.0	21.1	20.7		
											20.0	465.0	20.7			
7521	06-07-2021	RMC	M25	SCPL		139	Col	1	4-8-21	29	25.0	595.0	26.4			
											25.0	590.0	26.2	26.4		
											25.0	595.0	26.4			
7522	06-07-2021	RMC	M20	SCPL		145	plinth		4-8-21	29	20.0	465.0	20.7			
											20.0	475.0	21.1	20.7		
											20.0	460.0	20.4			
7523	06-07-2021	RMC	M20	Ishaq		181	plinth		4-8-21	29	20.0	470.0	20.9			
											20.0	475.0	21.1	20.9		
											20.0	465.0	20.7			
7524	06-07-2021	RMC	M25	SCPL		133	Col	2	4-8-21	29	25.0	600.0	26.7			
											25.0	595.0	26.4	26.7		
											25.0	605.0	26.9			
7525	07-07-2021	RMC	M25	SCPL		122	Col	2	4-8-21	28	25.0	605.0	26.9			
											25.0	600.0	26.7	26.9		
											25.0	610.0	27.1			
7526	07-07-2021	RMC	M25	RCPL		110	Col	2	4-8-21	28	25.0	610.0	27.1			
											25.0	605.0	26.9	27.1		
											25.0	615.0	27.3			
7527	07-07-2021	RMC	M25	SCPL		135	Col	2	4-8-21	28	25.0	590.0	26.2			
											25.0	590.0	26.2	26.1		
											25.0	580.0	25.8			
7528	07-07-2021	RMC	M20	RCPL		111	slab	1	4-8-21	28	20.0	455.0	20.2			
											20.0	460.0	20.4	20.7		
											20.0	485.0	21.6			
7529	10-07-2021	RMC	M20	Ishaq		166	footing		7-8-21	28	-	450.0	20.0			
											20.0	455.0	20.2	20.5		
											20.0	480.0	21.3			
7530	10-07-2021	RMC	M20	Ishaq		167	footing		7-8-21	28	20.0	445.0	19.8			
											20.0	450.0	20.0	20.3		
											20.0	475.0	21.1			
7531	12-07-2021	RMC	M25	RCPL		107	Col	2	10-8-21	29	25.0	595.0	26.4			
											25.0	595.0	26.4	26.3		
											25.0	585.0	26.0			
7532	12-07-2021	RMC	M20	Shravan		149	footing		10-8-21	29	20.0	440.0	19.6			
											20.0	445.0	19.8	20.1		
											20.0	470.0	20.9			
7533	14-07-2021	RMC	M20	Ishaq		164	plinth		12-8-21	29	20.0	445.0	19.8			
											20.0	450.0	20.0	20.1		
											20.0	465.0	20.7			
7534	14-07-2021	RMC	M25	Ishaq		182	Col	1	12-8-21	29	25.0	590.0	26.2			
											25.0	590.0	26.2	26.1		
											25.0	580.0	25.8			
7535	14-07-2021	RMC	M20	SCPL		144	slab	1	12-8-21	29	20.0	450.0	20.0			
											20.0	455.0	20.2	20.4		
											20.0	470.0	20.9			
7536	15-07-2021	Site Mix	M25	SCPL		124	Col	3	12-8-21	28	25.0	585.0	26.0			
											25.0	585.0	26.0	25.9		
											25.0	575.0	25.6			

7537	16-07-2021	RMC	M20	RCPL		109	slab	1	12-8-21	27	20.0	455.0	20.2			
											20.0	460.0	20.4	20.6		
											20.0	475.0	21.1			
7538	16-07-2021	RMC	M20	SCPL		132	slab	2	12-8-21	27	20.0	460.0	20.4			
											20.0	465.0	20.7	20.8		
											20.0	480.0	21.3			
7539	16-07-2021	RMC	M20	RCPL		105	slab	3	12-8-21	27	20.0	465.0	20.7			
											20.0	470.0	20.9	21.0		
											20.0	485.0	21.6			
7540	17-07-2021	RMC	M25	Ishaq		163	Col	1	14-8-21	28	25.0	580.0	25.8			
											25.0	580.0	25.8	25.4		
											25.0	555.0	24.7			
7541	19-07-2021	RMC	M20	Ishaq		165	plinth		18-8-21	30	20.0	455.0	20.2			
											20.0	465.0	20.7	20.6		
											20.0	470.0	20.9			
7542	19-07-2021	RMC	M25	Ishaq		162	Col	1	18-8-21	30	25.0	585.0	26.0			
											25.0	585.0	26.0	25.6		
											25.0	560.0	24.9			
7543	19-07-2021	RMC	M20	SCPL		137	plinth		18-8-21	30	20.0	455.0	20.2			
											20.0	485.0	21.6	20.6		
											20.0	450.0	20.0			
7544	19-07-2021	RMC	M25	RCPL		111	Col	2	18-8-21	30	25.0	555.0	24.7			
											25.0	565.0	25.1	25.1		
											25.0	575.0	25.6			
7545	20-07-2021	RMC	M25	SCPL		145	Col	1	18-8-21	29	25.0	560.0	24.9			
											25.0	570.0	25.3	25.3		
											25.0	580.0	25.8			
7546	20-07-2021	RMC	M25	Ishaq		183	Col	1	18-8-21	29	25.0	565.0	25.1			
											25.0	575.0	25.6	25.6		
											25.0	585.0	26.0			
7547	20-07-2021	Site Mix	M25	SCPL		132	Col	3	18-8-21	29	25.0	570.0	25.3			
											25.0	570.0	25.3	25.5		
											25.0	580.0	25.8			
7548	23-07-2021	RMC	M25	SCPL		144	Col	2	21-8-21	29	25.0	575.0	25.6			
											25.0	585.0	26.0	25.9		
											25.0	590.0	26.2			
7549	23-07-2021	RMC	M20	SCPL		123	slab	2	21-8-21	29	20.0	445.0	19.8			
											20.0	445.0	19.8	19.6		
											20.0	430.0	19.1			
7550	23-07-2021	RMC	M20	RCPL		116	slab	3	21-8-21	29	20.0	450.0	20.0			
											20.0	450.0	20.0	20.2		
											20.0	465.0	20.7			
7551	24-07-2021	RMC	M25	Ishaq		181	Col	1	21-8-21	28	25.0	610.0	27.1			
											25.0	595.0	26.4	26.7		
											25.0	595.0	26.4			
7552	24-07-2021	RMC	M20	Ishaq		179	footing		21-8-21	28	20.0	455.0	20.2			
											20.0	460.0	20.4	20.3		
											20.0	455.0	20.2			
7553	24-07-2021	RMC	M20	RCPL		106	slab	1	21-8-21	28	20.0	460.0	20.4			
											20.0	465.0	20.7	20.9		
											20.0	485.0	21.6			
7556	28-07-2021	RMC	M25	Ishaq		165	Col	1	5-8-21	8	17.5	395.0	17.6			
											17.5	390.0	17.3	17.7		
											17.5	410.0	18.2			
7556	28-07-2021	RMC	M25	Ishaq		165	Col	1	25-8-21	28	25.0	595.0	26.4			
											25.0	590.0	26.2	26.6		
											25.0	610.0	27.1			
7557	29-07-2021	RMC	M25	Ishaq		164	Col	1	5-8-21	7	17.5	400.0	17.8			

											17.5	395.0	17.6	17.9		
											17.5	415.0	18.4			
7557	29-07-2021	RMC	M25	Ishaq		164	Col	1	25-8-21	27	25.0	590.0	26.2			
											25.0	585.0	26.0	25.7		
											25.0	560.0	24.9			
7558	29-07-2021	RMC	M20	RCPL		118	slab	1	7-8-21	9	14.0	325.0	14.4			
											14.0	325.0	14.4	14.4		
											14.0	320.0	14.2			
7558	29-07-2021	RMC	M20	RCPL		118	slab	1	28-8-21	30	20.0	455.0	20.2			
											20.0	455.0	20.2	20.4		
											20.0	465.0	20.7			
7559	31-07-2021	RMC	M20	SCPL		135	slab	2	7-8-21	7	14.0	330.0	14.7			
											14.0	330.0	14.7	14.6		
											14.0	325.0	14.4			
7559	31-07-2021	RMC	M20	SCPL		135	slab	2	28-8-21	28	20.0	450.0	20.0			
											20.0	450.0	20.0	20.1		
											20.0	460.0	20.4			
7560	31-07-2021	RMC	M20	SCPL		133	slab	2	7-8-21	7	14.0	335.0	14.9			
											14.0	335.0	14.9	14.8		
											14.0	330.0	14.7			
7560	31-07-2021	RMC	M20	SCPL		133	slab	2	28-8-21	28	20.0	460.0	20.4			
											20.0	460.0	20.4	20.6		
											20.0	470.0	20.9			
7561	31-07-2021	RMC	M20	SCPL		134	slab	2	7-8-21	7	14.0	340.0	15.1			
											14.0	340.0	15.1	15.2		
											14.0	345.0	15.3			
7561	31-07-2021	RMC	M20	SCPL		134	slab	2	28-8-21	28	20.0	465.0	20.7			
											20.0	465.0	20.7	20.8		
											20.0	475.0	21.1			
7562	02-08-2021	RMC	M20	SCPL		122	slab	2	11-8-21	9	14.0	325.0	14.4			
											14.0	325.0	14.4	14.2		
											14.0	310.0	13.8			
7562	02-08-2021	RMC	M20	SCPL		122	slab	2	31-8-21	29	20.0	470.0	20.9			
											20.0	470.0	20.9	21.1		
											20.0	485.0	21.6			
7563	03-08-2021	RMC	M20	Ishaq		162	slab	1	11-8-21	8	14.0	330.0	14.7			
											14.0	330.0	14.7	14.4		
											14.0	315.0	14.0			
7563	03-08-2021	RMC	M20	Ishaq		162	slab	1	31-8-21	28	20.0	450.0	20.0			
											20.0	460.0	20.4	20.5		
											20.0	475.0	21.1			
7564	03-08-2021	RMC	M20	Ishaq		163	slab	1	11-8-21	8	14.0	315.0	14.0			
											14.0	305.0	13.6	13.9		
											14.0	315.0	14.0			
7564	03-08-2021	RMC	M20	Ishaq		163	slab	1	31-8-21	28	20.0	455.0	20.2			
											20.0	465.0	20.7	20.8		
											20.0	485.0	21.6			
7565	04-08-2021	RMC	M20	RCPL		115	slab	3	11-8-21	7	14.0	320.0	14.2			
											14.0	320.0	14.2	14.1		
											14.0	310.0	13.8			
7566	04-08-2021	RMC	M20	RCPL		114	slab	2	11-8-21	7	14.0	325.0	14.4			
											14.0	325.0	14.4	14.3		
											14.0	315.0	14.0			
7567	04-08-2021	RMC	M20	RCPL		117	slab	2	11-8-21	7	14.0	330.0	14.7			
											14.0	330.0	14.7	14.5		
											14.0	320.0	14.2			
7568	04-08-2021	RMC	M20	RCPL		103	slab	3	11-8-21	7	14.0	335.0	14.9			
											14.0	330.0	14.7	14.7		
											14.0	325.0	14.4			
7569	05-08-2021	RMC	M25	RCPL		109	Col	2	14-8-21	9	14.0	345.0	15.3			

											14.0	350.0	15.6	15.2		
											14.0	330.0	14.7			
7570	05-08-2021	RMC	M20	Ishaq		178	footing		14-8-21	9	14.0	350.0	15.6			
											14.0	345.0	15.3	15.3		
											14.0	340.0	15.1			
7571	06-08-2021	RMC	M20	RCPL		108	slab	1	14-8-21	8	14.0	320.0	14.2			
											14.0	310.0	13.8	14.0		
											14.0	315.0	14.0			
7572	06-08-2021	RMC	M20	RCPL		119	slab	1	14-8-21	8	14.0	325.0	14.4			
											14.0	315.0	14.0	14.1		
											14.0	315.0	14.0			
7573	07-08-2021	Site Mix	M25	SCPL		133	Col	3	14-8-21	7	17.5	395.0	17.6			
											17.5	415.0	18.4	17.9		
											17.5	395.0	17.6			
7574	07-08-2021	Site Mix	M25	SCPL		134	Col	3	14-8-21	7	17.5	390.0	17.3			
											17.5	410.0	18.2	17.7		
											17.5	395.0	17.6			
7575	07-08-2021	Site Mix	M25	SCPL		135	Col	3	14-8-21	7	17.5	405.0	18.0			
											17.5	410.0	18.2	17.9		
											17.5	390.0	17.3			
7576	07-08-2021	Site Mix	M25	SCPL		122	Col	3	14-8-21	7	17.5	410.0	18.2			
											17.5	415.0	18.4	18.1		
											17.5	395.0	17.6			
7577	07-08-2021	RMC	M25	RCPL		106	Col	2	14-8-21	7	17.5	385.0	17.1			
											17.5	385.0	17.1	17.3		
											17.5	395.0	17.6			
7578	14-08-2021	RMC	M20	RCPL		107	slab	2	21-8-21	7	14.0	325.0	14.4			
											14.0	315.0	14.0	14.1		
											14.0	315.0	14.0			
7579	14-08-2021	RMC	M20	RCPL		120	slab	1	21-8-21	7	14.0	330.0	14.7			
											14.0	320.0	14.2	14.4		
											14.0	320.0	14.2			
7580	14-08-2021	RMC	M20	Ishaq		181	slab	1	21-8-21	7	14.0	335.0	14.9			
											14.0	325.0	14.4	14.5		
											14.0	320.0	14.2			
7581	14-08-2021	RMC	M20	Ishaq		183	slab	1	21-8-21	7	14.0	340.0	15.1			
											14.0	325.0	14.4	14.7		
											14.0	325.0	14.4			
7582	20-08-2021	RMC	M20	SCPL		122	slab	3	28-8-21	8	14.0	345.0	15.3			
											14.0	335.0	14.9	14.9		
											14.0	325.0	14.4			
7583	20-08-2021	RMC	M20	SCPL		123	slab	3	28-8-21	8	14.0	350.0	15.6			
											14.0	320.0	14.2	14.5		
											14.0	310.0	13.8			
7584	20-08-2021	RMC	M20	SCPL		124	slab	3	28-8-21	8	14.0	310.0	13.8			
											14.0	310.0	13.8	14.0		
											14.0	325.0	14.4			
7585	20-08-2021	RMC	M20	SCPL		132	slab	3	28-8-21	8	14.0	315.0	14.0			
											14.0	315.0	14.0	14.2		
											14.0	330.0	14.7			
7586	20-08-2021	RMC	M20	SCPL		133	slab	3	28-8-21	8	14.0	320.0	14.2			
											14.0	320.0	14.2	14.3		