

QC - Concrete Cube Testing Report.																
Company:		SOVLLP														
Project:		SOV														
Report for Month:		Aug - Sept = 2021.														
Prepared By:		QC Team														
Date:		05-10-2021														
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks	
7565	04-08-2021	RMC	M20	RCPL		115	slab	3	1-9-21	28	20.0	455.0	20.2			
											20.0	470.0	20.9	20.1		
											20.0	430.0	19.1			
7566	04-08-2021	RMC	M20	RCPL		114	slab	2	1-9-21	28	20.0	460.0	20.4			
											20.0	475.0	21.1	20.3		
											20.0	435.0	19.3			
7567	04-08-2021	RMC	M20	RCPL		117	slab	2	1-9-21	28	20.0	465.0	20.7			
											20.0	480.0	21.3	20.5		
											20.0	440.0	19.6			
7568	04-08-2021	RMC	M20	RCPL		103	slab	3	1-9-21	28	20.0	470.0	20.9			
											20.0	485.0	21.6	20.7		
											20.0	445.0	19.8			
7569	05-08-2021	RMC	M25	RCPL		109	Col	2	3-9-21	29	25.0	570.0	25.3			
											25.0	560.0	24.9	24.9		
											25.0	550.0	24.4			
7570	05-08-2021	RMC	M20	Ishaq		178	footing		3-9-21	29	20.0	475.0	21.1			
											20.0	490.0	21.8	21.0		
											20.0	450.0	20.0			
7571	06-08-2021	RMC	M20	RCPL		108	slab	1	3-9-21	28	20.0	480.0	21.3			
											20.0	495.0	22.0	21.2		
											20.0	455.0	20.2			
7572	06-08-2021	RMC	M20	RCPL		119	slab	1	3-9-21	28	20.0	470.0	20.9			
											20.0	490.0	21.8	20.9		
											20.0	450.0	20.0			
7573	07-08-2021	Site Mix	M25	SCPL		133	Col	3	3-9-21	27	25.0	575.0	25.6			
											25.0	565.0	25.1	25.1		
											25.0	555.0	24.7			
7574	07-08-2021	Site Mix	M25	SCPL		134	Col	3	3-9-21	27	25.0	580.0	25.8			
											25.0	560.0	24.9	25.1		
											25.0	555.0	24.7			
7575	07-08-2021	Site Mix	M25	SCPL		135	Col	3	3-9-21	27	25.0	585.0	26.0			
											25.0	550.0	24.4	24.8		
											25.0	540.0	24.0			
7576	07-08-2021	Site Mix	M25	SCPL		122	Col	3	3-9-21	27	25.0	595.0	26.4			
											25.0	590.0	26.2	26.2		
											25.0	585.0	26.0			
7577	07-08-2021	RMC	M25	RCPL		106	Col	2	3-9-21	27	25.0	565.0	25.1			
											25.0	560.0	24.9	24.9		
											25.0	555.0	24.7			
7578	14-08-2021	RMC	M20	RCPL		107	slab	2	12-9-21	29	20.0	445.0	19.8			
											20.0	445.0	19.8	20.2		
											20.0	475.0	21.1			

7579	14-08-2021	RMC	M20	RCPL		120	slab	1	12-9-21	29	20.0	450.0	20.0			
											20.0	450.0	20.0	20.4		
											20.0	480.0	21.3			
7580	14-08-2021	RMC	M20	Ishaq		181	slab	1	12-9-21	29	20.0	455.0	20.2			
											20.0	455.0	20.2	20.5		
											20.0	475.0	21.1			
7581	14-08-2021	RMC	M20	Ishaq		183	slab	1	12-9-21	29	20.0	460.0	20.4			
											20.0	460.0	20.4	20.5		
											20.0	465.0	20.7			
7582	20-08-2021	RMC	M20	SCPL		122	slab	3	18-9-21	29	20.0	445.0	19.8			
											20.0	445.0	19.8	20.1		
											20.0	465.0	20.7			
7583	20-08-2021	RMC	M20	SCPL		123	slab	3	18-9-21	29	20.0	450.0	20.0			
											20.0	450.0	20.0	20.3		
											20.0	470.0	20.9			
7584	20-08-2021	RMC	M20	SCPL		124	slab	3	18-9-21	29	20.0	455.0	20.2			
											20.0	455.0	20.2	20.5		
											20.0	475.0	21.1			
7585	20-08-2021	RMC	M20	SCPL		132	slab	3	18-9-21	29	20.0	455.0	20.2			
											20.0	460.0	20.4	20.5		
											20.0	470.0	20.9			
7586	20-08-2021	RMC	M20	SCPL		133	slab	3	18-9-21	29	20.0	460.0	20.4			
											20.0	465.0	20.7	20.7		
											20.0	475.0	21.1			
7587	20-08-2021	RMC	M20	SCPL		134	slab	3	18-9-21	29	20.0	465.0	20.7			
											20.0	470.0	20.9	20.8		
											20.0	470.0	20.9			
7588	20-08-2021	RMC	M20	SCPL		135	slab	3	18-9-21	29	20.0	460.0	20.4			
											20.0	465.0	20.7	20.6		
											20.0	465.0	20.7			
7589	20-08-2021	RMC	M20	SCPL		144	slab	2	18-9-21	29	20.0	460.0	20.4			
											20.0	465.0	20.7	20.4		
											20.0	455.0	20.2			
7590	20-08-2021	RMC	M25	RCPL		108	Col	2	18-9-21	29	25.0	585.0	26.0			
											25.0	585.0	26.0	26.1		
											25.0	595.0	26.4			
7591	24-08-2021	RMC	M20	Ishaq		164	slab	1	22-9-21	29	20.0	440.0	19.6			
											20.0	450.0	20.0	20.0		
											20.0	460.0	20.4			
7592	24-08-2021	RMC	M20	Ishaq		165	slab	1	22-9-21	29	20.0	445.0	19.8			
											20.0	460.0	20.4	20.1		
											20.0	450.0	20.0			
7593	24-08-2021	RMC	M20	RCPL		113	slab	2	22-9-21	29	20.0	450.0	20.0			
											20.0	465.0	20.7	20.3		
											20.0	455.0	20.2			
7594	24-08-2021	RMC	M20	SCPL		139	slab	1	22-9-21	29	20.0	455.0	20.2			
											20.0	470.0	20.9	20.5		
											20.0	460.0	20.4			

7595	24-08-2021	RMC	M20	SCPL		143	slab	1	22-9-21	29	20.0 20.0 20.0	460.0 475.0 465.0	20.4 21.1 20.7				
7596	25-08-2021	RMC	M25	SCPL		137	Col	1	2-9-21	8	17.5 17.5 17.5	410.0 390.0 395.0	18.2 17.3 17.6	17.7			
7596	25-08-2021	RMC	M25	SCPL		137	Col	1	23-9-21	29	25.0 25.0 25.0	595.0 590.0 595.0	26.4 26.2 26.4	26.4			
7597	27-08-2021	RMC	M20	SCPL		140	slab	1	2-9-21	6	14.0 14.0 14.0	325.0 325.0 345.0	14.4 14.4 15.3	14.7			
7597	27-08-2021	RMC	M20	SCPL		140	slab	1	23-9-21	27	20.0 20.0 20.0	445.0 450.0 465.0	19.8 20.0 20.7	20.1			
7598	27-08-2021	RMC	M20	SCPL		138	slab	1	2-9-21	6	14.0 14.0 14.0	310.0 310.0 305.0	13.8 13.8 13.6	13.7			
7598	27-08-2021	RMC	M20	SCPL		138	slab	1	23-9-21	27	20.0 20.0 20.0	450.0 455.0 460.0	20.0 20.2 20.4	20.2			
7599	27-08-2021	Site Mix	M25	SCPL		144	Col	3	4-9-21	8	17.5 17.5 17.5	415.0 390.0 395.0	18.4 17.3 17.6	17.8			
7599	27-08-2021	Site Mix	M25	SCPL		144	Col	3	25-9-21	29	25.0 25.0 25.0	570.0 590.0 590.0	25.3 26.2 26.2	25.9			