

QC - Concrete Cube Testing Report.																		
Company:		MMR(LLP)																
Project:		GHT																
Report for Month:		Sept - Oct = 2021.																
Prepared By:		QC Team																
Date:		10-11-2021																
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks			
18178	09-09-2021	Rmc	M20	Homeline	B-606-609	slab	8	8-10-21	29		20.0	445.0	19.8					
											20.0	460.0	20.4	20.4				
											20.0	475.0	21.1					
18179	10-09-2021	Site Mix	M25	Homeline	A-101,102,116	Columns	3	8-10-21	28		25.0	545.0	24.2					
											25.0	595.0	26.4	25.7				
											25.0	595.0	26.4					
18180	17-09-2021	Rmc	M20	Homeline	A-103-105,115	slab	2	15-10-21	28		20.0	450.0	20.0					
											20.0	465.0	20.7	20.7				
											20.0	480.0	21.3					
18181	21-09-2021	Site Mix	M25	Homeline	B-706-709	Columns	9	29-9-21	8		17.5	410.0	18.2					
											17.5	395.0	17.6	17.6				
											17.5	380.0	16.9					
18181	21-09-2021	Site Mix	M25	Homeline	B-706-709	Columns	9	20-10-21	29		25.0	540.0	24.0					
											25.0	590.0	26.2	25.4				
											25.0	585.0	26.0					
18182	25-09-2021	Site Mix	M25	Homeline	A-104,105,114	Columns	3	3-10-21	8		17.5	425.0	18.9					
											17.5	395.0	17.6	17.8				
											17.5	380.0	16.9					
18182	25-09-2021	Site Mix	M25	Homeline	A-104,105,114	Columns	3	23-10-21	28		25.0	550.0	24.4					
											25.0	585.0	26.0	25.4				
											25.0	580.0	25.8					
18183	05-10-2021	Rmc	M20	Homeline	A-101,102,116	slab	3	13-10-21	8		14.0	320.0	14.2					
											14.0	310.0	13.8	14.3				
											14.0	335.0	14.9					
18183	05-10-2021	Rmc	M20	Homeline	A-101,102,116	slab	3	4-11-21	30		20.0	455.0	20.2					
											20.0	470.0	20.9	20.9				
											20.0	485.0	21.6					
18184	09-10-2021	Rmc	M20	Homeline	B-706-709	slab	9	16-10-21	7		14.0	325.0	14.4					
											14.0	325.0	14.4	14.5				
											14.0	330.0	14.7					
18184	09-10-2021	Rmc	M20	Homeline	B-706-709	slab	9	6-11-21	28		20.0	450.0	20.0					
											20.0	465.0	20.7	20.7				
											20.0	485.0	21.6					