

Sl. No.

1002

Date : 12th Oct 2021


Consultant Inspection Report


by K. Hemant Kumar / SUPCL

Observation for slab verification (Fabrication) at
Level 110.3 between Grids A-F and 6-12.

- ① All Graps to be filled properly before concreting
- ② Slab top and bottom levels are to be recorded properly.
- ③ All levels to be fixed as per arch drawings before concreting.
- ④ Development length to be provided for all extra bars.
- ⑤ Cleaning to be done before concreting.
- ⑥ Slump to be checked for all batches.
- ⑦ cubes to be collected for all batching.
- ⑧ Guard rings to be provided for all columns.
- ⑨ Proper precautions to be taken to protect from rain during concreting.
- ⑩ Counter props to be provided at basement level.

All above points to be attended and approval to be taken from site Incharge before concreting.


Engineer Sign.


Consultant Sign.
(K. Hemant Kumar)