

QC - Concrete Cube Testing Report.																
Company:		SOVLLP														
Project:		SOV														
Report for Month:		Dec - Jan = 2022.														
Prepared By:		QC Team														
Date:		06-02-2022														
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No.	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks	
7752	29-12-2021	Rmc	M20	Ishaq		169	Footings		6-1-22	8	14.0	345.0	15.3			
											14.0	335.0	14.9	15.2		
											14.0	345.0	15.3			
7752	29-12-2021	Rmc	M20	Ishaq		169	Footings		25-1-22	27	20.0	425.0	18.9			
											20.0	430.0	19.1	19.5		
											20.0	460.0	20.4			
7753	29-12-2021	Rmc	M20	Ishaq		176	Footings		6-1-22	8	14.0	340.0	15.1			
											14.0	325.0	14.4	14.7		
											14.0	330.0	14.7			
7753	29-12-2021	Rmc	M20	Ishaq		176	Footings		25-1-22	27	20.0	470.0	20.9			
											20.0	440.0	19.6	20.1		
											20.0	450.0	20.0			
7754	29-12-2021	Rmc	M20	Mhpl		Commercial	Slab	2	6-1-22	8	14.0	345.0	15.3			
											14.0	330.0	14.7	15.1		
											14.0	345.0	15.3			
7754	29-12-2021	Rmc	M20	Mhpl		Commercial	Slab	2	25-1-22	27	20.0	475.0	21.1			
											20.0	445.0	19.8	20.4		
											20.0	455.0	20.2			
7755	31-12-2021	Rmc	M25	Ishaq		184	col	2	8-1-22	8	17.5	395.0	17.6			
											17.5	395.0	17.6	17.6		
											17.5	395.0	17.6			
7755	31-12-2021	Rmc	M25	Ishaq		184	col	2	28-1-22	28	25.0	575.0	25.6			
											25.0	585.0	26.0	25.9		
											25.0	585.0	26.0			
7756	31-12-2021	Rmc	M25	SCPL		152	col	2	8-1-22	8	17.5	405.0	18.0			
											17.5	395.0	17.6	17.7		
											17.5	395.0	17.6			
7756	31-12-2021	Rmc	M25	SCPL		152	col	2	28-1-22	28	25.0	580.0	25.8			
											25.0	570.0	25.3	25.6		
											25.0	575.0	25.6			
7757	05-01-2022	Rmc	M25	SCPL		155	col	1	13-1-22	8	17.5	410.0	18.2			
											17.5	405.0	18.0	17.9		
											17.5	390.0	17.3			
7757	05-01-2022	Rmc	M25	SCPL		155	col	1	3-2-22	29	25.0	575.0	25.6			
											25.0	565.0	25.1	25.3		
											25.0	570.0	25.3			
7758	11-01-2022	Rmc	M20	Ishaq		176	plinth		20-1-22	9	14.0	335.0	14.9			
											14.0	320.0	14.2	14.5		
											14.0	325.0	14.4			
7759	12-01-2022	Rmc	M25	Mhpl		Commercial	col	3	20-1-22	8	17.5	415.0	18.4			
											17.5	410.0	18.2	18.1		
											17.5	395.0	17.6			

[illegible]