

QC - Concrete Cube Testing Report.															
Company:		SOVLLP													
Project:		SOV													
Report for Month:		Dec - Jan = 2022.													
Prepared By:		QC Team													
Date:		06-02-2022													
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
7758	11-01-2022	Rmc	M20	Ishaq		176	plinth		10-2-22	30	20.0	455.0	20.2		
											20.0	435.0	19.3	20.1	
											20.0	465.0	20.7		
7759	12-01-2022	Rmc	M25	Mhpl		Commercial	col	3	10-2-22	29	25.0	585.0	26.0		
											25.0	575.0	25.6	25.5	
											25.0	560.0	24.9		
7760	13-01-2022	Rmc	M20	SCPL		159	Slab	1	10-2-22	28	20.0	460.0	20.4		
											20.0	475.0	21.1	20.3	
											20.0	434.0	19.3		
7761	13-01-2022	Rmc	M20	SCPL		156	Slab	2	10-2-22	28	20.0	465.0	20.7		
											20.0	445.0	19.8	20.5	
											20.0	475.0	21.1		
7762	13-01-2022	Rmc	M20	Ishaq		186	Footings		10-2-22	28	20.0	475.0	21.1		
											20.0	455.0	20.2	20.9	
											20.0	480.0	21.3		
7763	21-01-2022	Rmc	M20	Ishaq		160	Slab	2	19-2-22	29	20.0	470.0	20.9		
											20.0	450.0	20.0	20.7	
											20.0	475.0	21.1		
7764	21-01-2022	Rmc	M20	Ishaq		161	Slab	2	19-2-22	29	20.0	465.0	20.7		
											20.0	445.0	19.8	20.4	
											20.0	470.0	20.9		
7765	21-01-2022	Rmc	M20	Ishaq		187	Footings		19-2-22	29	20.0	460.0	20.4		
											20.0	440.0	19.6	20.2	
											20.0	465.0	20.7		
7766	21-01-2022	Rmc	M20	SCPL		153	Slab	3	19-2-22	29	20.0	470.0	20.9		
											20.0	460.0	20.4	21.1	
											20.0	495.0	22.0		
7767	21-01-2022	Rmc	M25	Ishaq		185	col	2	19-2-22	29	25.0	555.0	24.7		
											25.0	565.0	25.1	25.1	
											25.0	575.0	25.6		
7768	24-01-2022	Rmc	M20	Ishaq		178	plinth		23-2-22	30	20.0	465.0	20.7		
											20.0	450.0	20.0	20.8	
											20.0	490.0	21.8		
7769	24-01-2022	Rmc	M20	SCPL		150	plinth		23-2-22	30	20.0	455.0	20.2		
											20.0	440.0	19.6	20.4	
											20.0	485.0	21.6		
7770	28-01-2022	Rmc	M20	Ishaq		177	plinth		23-2-22	26	20.0	460.0	20.4		
											20.0	440.0	19.6	20.3	
											20.0	470.0	20.9		
7771	03-02-2022	Rmc	M20	SCPL		154	Slab	1	12-2-22	9	14.0	330.0	14.7		
											14.0	325.0	14.4	14.5	
											14.0	325.0	14.4		
7772	04-02-2022	Rmc	M20	Ishaq		167	plinth		12-2-22	8	14.0	325.0	14.4		
											14.0	325.0	14.4	14.2	
											14.0	310.0	13.8		